


OIL ANALYSIS REPORT

Sample Rating Trend







745000-361561

Component

Natural Gas Engine

PETRO CANADA DURON GEO LD 15W40 (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.


(LTR)		May2021 (Det2021 Nov2021 May20	22 Mar2023 Jun2023 Oct2023	Jan2024	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0106980	GFL0094262	GFL0085395
Sample Date		Client Info		06 Jan 2024	03 Oct 2023	23 Jun 2023
Machine Age	hrs	Client Info		21828	34657	34624
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	19	13	4
Chromium	ppm	ASTM D5185m	>4	<1	1	0
Nickel	ppm	ASTM D5185m	>2	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	1	2	0
Lead	ppm	ASTM D5185m	>30	<1	0	0
Copper	ppm	ASTM D5185m	>35	<1	1	<1
Tin	ppm	ASTM D5185m	>4	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	3	6	26
Barium	ppm	ASTM D5185m	5	0	0	0
Molybdenum	ppm	ASTM D5185m	50	57	54	52
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	560	876	554	534
Calcium	ppm	ASTM D5185m	1510	1052	1516	1544
Phosphorus	ppm	ASTM D5185m	780	1071	709	779
Zinc	ppm	ASTM D5185m	870	1259	979	948
Sulfur	ppm	ASTM D5185m	2040	3036	2649	2534
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	3	4	2
Sodium	ppm	ASTM D5185m		15	8	<1
Potassium	ppm	ASTM D5185m	>20	8	1	2
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		1.5	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	10.0	10.3	8.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.7	19.9	19.5
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	16.5	17.3	17.4

Base Number (BN) mg KOH/g ASTM D2896 10.2 8.6



OIL ANALYSIS REPORT






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPERTIES		method				history2	
Visc @ 100°C	cSt	ASTM D445	15.1	12.7	14.6	14.8	

GRAPHS


Ferrous Alloys















6.0

0.0



GFL Environmental - 882 - Gainesville

5002 SW 41st Blvd Gainesville, FL US 32608

Contact: ROBERT CLARK

robert.clark@gflenv.com





Certificate L2367

Laboratory Sample No. Lab Number Test Package : FLEET

: GFL0106980 : 06056388 Unique Number : 10822337

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 10 Jan 2024 Diagnosed : 11 Jan 2024 Diagnostician : Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: