

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id 811009

Component Diesel Engine Fluid DIESEL ENGINE OIL SAE 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0108346	GFL0098226	GFL0098247
Sample Date		Client Info		05 Jan 2024	12 Dec 2023	16 Nov 2023
Machine Age	hrs	Client Info		7787	7669	7498
Oil Age	hrs	Client Info		7787	7669	7498
Oil Changed	1115	Client Info		N/A	N/A	N/A
Sample Status		Client Into		NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0	<1.0	<1.0
Water		WC Method	>0.2	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	4	11	13
Chromium	ppm	ASTM D5185m	>20	0	<1	<1
Nickel	ppm	ASTM D5185m	>4	<1	1	2
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>20	1	2	2
Lead	ppm	ASTM D5185m	>40	<1	<1	<1
Copper	ppm	ASTM D5185m	>330	7	4	3
Tin	ppm	ASTM D5185m	>15	<1	1	<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
				0	0	
ADDITIVES		method	limit/base	current	history1	history2
ADDITIVES Boron	ppm		limit/base 250			
		method		current	history1	history2
Boron	ppm	method ASTM D5185m	250	current 11	history1 6	history2 6
Boron Barium	ppm ppm	method ASTM D5185m ASTM D5185m	250 10	current 11 0	history1 6 0	history2 6 <1
Boron Barium Molybdenum	ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m	250 10	current 11 0 56	history1 6 0 58	history2 6 <1 66
Boron Barium Molybdenum Manganese	ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100	current 11 0 56 <1	history1 6 0 58 <1	history2 6 <1 66 0
Boron Barium Molybdenum Manganese Magnesium	ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450	current 11 0 56 <1 923	history1 6 0 58 <1 932	history2 6 <1 66 0 1049
Boron Barium Molybdenum Manganese Magnesium Calcium	ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000	Current 11 0 56 <1 923 1081	history1 6 0 58 <1 932 1051	history2 6 <1 66 0 1049 1161
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus	ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150	Current 11 0 56 <1 923 1081 1033	history1 6 0 58 <1 932 1051 978	history2 6 <1 66 0 1049 1161 1024
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350	current 11 0 56 <1 923 1081 1033 1224	history1 6 0 58 <1 932 1051 978 1270	history2 6 <1 66 0 1049 1161 1024 1344
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur	ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350 4250	Current 11 0 56 <1 923 1081 1033 1224 3065	history1 6 0 58 <1 932 1051 978 1270 2736	history2 6 <1 66 0 1049 1161 1024 1344 3473
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN	ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250	current 11 0 56 <1 923 1081 1033 1224 3065 current	history1 6 0 58 <1 932 1051 978 1270 2736 history1	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350 4250 limit/base >25 >216	current 11 0 56 <1 923 1081 1033 1224 3065 current 3	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350 4250 limit/base >25 >216	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350 4250 limit/base >25 >216 >20	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1 1	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1 0	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2 2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot %	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350 4250 Imit/base >25 >216 >216 >20 Imit/base >3	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1 1 current 0.3	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1 0 history1 0.7	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2 2 history2 0.6
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m	250 10 100 450 3000 1150 1350 4250 Imit/base >25 >216 >20 Imit/base	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1 1 current	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1 0 history1	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2 2 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration	ppm ppm ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm	method ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 Iimit/base >25 >216 >20 Iimit/base >3 >20	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1 1 current 0.3 6.1	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1 0 history1 0.7 9.2	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2 history2 0.6 8.2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm ppm	method ASTM D5185m ASTM D7844 *ASTM D7624 *ASTM D7415 method	250 10 100 450 3000 1150 1350 4250 20 216 >216 >216 >20 >20 >3 >20 >30 >30	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1 0.3 6.1 18.0 current	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1 0 history1 0.7 9.2 20.4 history1	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2 history2 0.6 8.2 19.9 history2
Boron Barium Molybdenum Manganese Magnesium Calcium Phosphorus Zinc Sulfur CONTAMINAN Silicon Sodium Potassium INFRA-RED Soot % Nitration Sulfation	ppm ppm ppm ppm ppm ppm ppm ppm ppm TS ppm ppm ppm	method ASTM D5185m ASTM D5185m	250 10 100 450 3000 1150 1350 4250 imit/base >25 >216 >20 imit/base >3 >20 >30	current 11 0 56 <1 923 1081 1033 1224 3065 current 3 <1 1 current 0.3 6.1 18.0	history1 6 0 58 <1 932 1051 978 1270 2736 history1 4 <1 0 history1 0.7 9.2 20.4	history2 6 <1 66 0 1049 1161 1024 1344 3473 history2 5 2 history2 0.6 8.2 19.9





OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	13.8	13.7	13.4
GRAPHS						





* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Submitted By: TECHNICIAN ACCOUNT

Т:

F: