




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**810058**

Component  
**Diesel Engine**

Fluid  
**PETRO CANADA DURON SHP 15W40 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>GFL0104552</b>	GFL0092623	GFL0082504
Sample Date	Client Info	<b>17 Jan 2024</b>	18 Oct 2023	14 Jul 2023
Machine Age	hrs	<b>4023</b>	3325	2905
Oil Age	hrs	<b>520</b>	420	605
Oil Changed	Client Info	<b>Not Changed</b>	Not Changed	Changed
Sample Status		<b>NORMAL</b>	NORMAL	ABNORMAL

## CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >5	<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method >0.2	<b>NEG</b>	NEG	NEG
Glycol	WC Method	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >110	<b>1</b>	5	17
Chromium	ppm ASTM D5185m >4	<b>&lt;1</b>	<1	<1
Nickel	ppm ASTM D5185m >2	<b>0</b>	0	0
Titanium	ppm ASTM D5185m	<b>0</b>	0	0
Silver	ppm ASTM D5185m >2	<b>0</b>	<1	<1
Aluminum	ppm ASTM D5185m >25	<b>1</b>	4	▲ 13
Lead	ppm ASTM D5185m >45	<b>0</b>	0	0
Copper	ppm ASTM D5185m >85	<b>&lt;1</b>	<1	3
Tin	ppm ASTM D5185m >4	<b>0</b>	0	<1
Vanadium	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 0	<b>&lt;1</b>	0	10
Barium	ppm ASTM D5185m 0	<b>0</b>	0	<1
Molybdenum	ppm ASTM D5185m 60	<b>53</b>	60	42
Manganese	ppm ASTM D5185m 0	<b>0</b>	<1	<1
Magnesium	ppm ASTM D5185m 1010	<b>942</b>	967	869
Calcium	ppm ASTM D5185m 1070	<b>999</b>	1050	1172
Phosphorus	ppm ASTM D5185m 1150	<b>1040</b>	1068	809
Zinc	ppm ASTM D5185m 1270	<b>1200</b>	1306	1014
Sulfur	ppm ASTM D5185m 2060	<b>3111</b>	2985	2731

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >30	<b>3</b>	3	▲ 32
Sodium	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Potassium	ppm ASTM D5185m >20	<b>2</b>	10	15

## INFRA-RED



method	limit/base	current	history1	history2
Soot %	% *ASTM D7844 >3	<b>0.1</b>	0.4	0.2
Nitration	Abs/cm *ASTM D7624 >20	<b>4.9</b>	7.3	6.8
Sulfation	Abs/.1mm *ASTM D7415 >30	<b>17.5</b>	19.3	21.7

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414 >25	<b>13.3</b>	14.9	18.9
Base Number (BN)	mg KOH/g ASTM D2896 9.8	<b>9.2</b>	8.4	8.1







# OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.4	14.1	13.6

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : GFL0104552      Recieved : 22 Jan 2024  
 Lab Number : 06067488      Diagnosed : 23 Jan 2024  
 Unique Number : 10844165      Diagnostician : Wes Davis  
 Test Package : FLEET

GFL Environmental - 947 - WB Horicon HC  
 N7296 County Rd V  
 Horicon, WI  
 US 53032  
 Contact: Tim Kieffer  
 tim.kieffer@gflenv.com  
 T: (608)219-0288  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)