

OIL ANALYSIS REPORT

[24A] 24A FILM TO-GB

Gearbox

MOBIL MOBILGEAR 600 XP 220 (--- GAL)

Sample Rating Trend **NORMAL**

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jan2024		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0076337		
Sample Date		Client Info		11 Jan 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		13410		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184		5		
Iron	ppm	ASTM D5185m	>200	15		
Chromium	ppm	ASTM D5185m	>15	0		
Nickel	ppm	ASTM D5185m	>15	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>100	0		
Copper	ppm	ASTM D5185m	>200	2		
Tin	ppm	ASTM D5185m	>25	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		16		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		<1		
Calcium	ppm	ASTM D5185m		3		
Phosphorus	ppm	ASTM D5185m		275		
Zinc	ppm	ASTM D5185m		4		
Sulfur	ppm	ASTM D5185m		7449		
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	7		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRAI	OATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.50		



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number **Unique Number**

: PCA0076337 : 06070081 : 10846758

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 24 Jan 2024 Recieved Diagnosed : 25 Jan 2024 Diagnostician

: Wes Davis

Test Package : PLANT Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **ACHILLES USA INC**

1407 80TH STREET SW EVERETT, WA

US 98203 Contact: TONY DEHLER tdehler@achillesusa.com T: (425)438-4681

Submitted By: WILL POTTER

F: