


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KOMATSU WA380-8 30-49 (S/N A74180)
Component
Diesel Engine
Fluid
PETRO CANADA DURON XL SYN BLEND 15W40 (7 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0095028	PCA0056846	PCA0036046
Sample Date	Client Info	14 Nov 2023	25 Oct 2022	26 Sep 2021
Machine Age	hrs	10144	8878	8009
Oil Age	hrs	700	869	149
Oil Changed	Client Info	Changed	Changed	Not Changed
Sample Status		NORMAL	NORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >5	<1.0	1.0	▲ 5.4
Water	WC Method >0.2	NEG	NEG	NEG
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >100	9	28	5
Chromium	ppm ASTM D5185m >20	<1	2	<1
Nickel	ppm ASTM D5185m >4	0	0	0
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m >3	0	0	<1
Aluminum	ppm ASTM D5185m >20	2	2	<1
Lead	ppm ASTM D5185m >40	0	0	0
Copper	ppm ASTM D5185m >330	1	2	<1
Tin	ppm ASTM D5185m >15	<1	<1	<1
Antimony	ppm ASTM D5185m	---	---	0
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 1	14	4	7
Barium	ppm ASTM D5185m 1	0	0	0
Molybdenum	ppm ASTM D5185m 60	49	63	55
Manganese	ppm ASTM D5185m 1	<1	<1	<1
Magnesium	ppm ASTM D5185m 1010	683	898	848
Calcium	ppm ASTM D5185m 1070	1188	1243	1019
Phosphorus	ppm ASTM D5185m 1150	927	1029	970
Zinc	ppm ASTM D5185m 1270	1096	1296	1151
Sulfur	ppm ASTM D5185m 2060	2752	3612	2698

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >25	3	3	<1
Sodium	ppm ASTM D5185m	0	<1	2
Potassium	ppm ASTM D5185m >20	0	2	0



INFRA-RED

method	limit/base	current	history1	history2
Soot %	% *ASTM D7844 >3	0.8	1.1	0.4
Nitration	Abs/cm *ASTM D7624 >20	10.1	13.2	7.9
Sulfation	Abs/.1mm *ASTM D7415 >30	21.0	25.2	19.3

FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414 >25	16.0	20.4	15.1
Base Number (BN)	mg KOH/g ASTM D2896 9.6	6.9	8.0	---









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	15.5	13.6	14.4	13.3

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0095028 **Recieved** : 25 Jan 2024
Lab Number : **06070250** **Diagnosed** : 25 Jan 2024
Unique Number : 10846927 **Diagnostician** : Wes Davis
Test Package : MOB 1 (Additional Tests: TBN)

JOHNSON DAVIS CONTRACTORS
 604 HILBRATH DR
 LANTANA, FL
 US 33462
 Contact: GENE GARDNER
 ggardner@johnsondavis.com
 T: (561)588-1170
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)