

PROBLEM SUMMARY


Sample Rating Trend

WATER

Area MIX ROOM D [98737429] KR-GR-000325-NORTH - 15000 LB MIXER (S/N MIX D - 11513074) Component **Gear Reducer** Fluic

PETRO CANADA 220 (48 LTR)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. (Customer Sample Comment: 98737429)

PROBLEMATIC TEST RESULTS									
Sample Status				SEVERE	SEVERE	ABNORMAL			
Water	%	ASTM D6304	>0.1	A 0.472	• 1.17	▲ 0.713			
ppm Water	ppm	ASTM D6304	>1000	4723	11700	A 7130			
Emulsified Water	scalar	*Visual	>0.1	6.2%	0.2%	0.2%			
Free Water	scalar	*Visual		 >10%	NEG	NEG			

Customer Id: KRAKIR Sample No.: PCA0108441 Lab Number: 06070451 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			
Check Water Access			?	We advise that you check for the source of water entry.			

HISTORICAL DIAGNOSIS



20 Oct 2023 Diag: Jonathan Hester

We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid.



view report

16 Aug 2023 Diag: Jonathan Hester



We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.All component wear rates are normal. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.

31 Jul 2023 Diag: Jonathan Hester

VISCOSITY



No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT

Iron

Silver

Lead

Tin

Zinc

Sample Rating Trend

WATER

MIX ROOM D [98737429] KR-GR-000325-NORTH - 15000 LB MIXER (S/N MIX D - 11513074) Component

Gear Reducer

PETRO CANADA 220 (48 LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. (Customer Sample Comment: 98737429)

Wear


All component wear rates are normal.

Contamination

Excessive free water present. There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Acid Number (AN)


mg KOH/g ASTM D8045


0.617 0.30





OIL ANALYSIS REPORT

Bottom










VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	🔺 LAYRD	🔺 MILKY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	6.2%	0.2%	0.2%
Free Water	scalar	*Visual		e >10%	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		234	227	227
SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Color						no image





Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Submitted By: Wilberto Pacheco Garcia

F: (660)627-5887