

# **OIL ANALYSIS REPORT**

#### Sample Rating Trend

### VISCOSITY

## DINNERS [98709269 AFTER] L21 KNIFE - DINNERS Component

Gearbox Fluic

## GEAR OIL ISO 150 (--- GAL)

#### DIAGNOSIS

#### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

#### Fluid Condition

The oil viscosity is higher than normal. Confirm oil type. The AN level is acceptable for this fluid.

<b>?</b> ]						
			Jan2024	Jan <sup>2</sup> 024		
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0108438	PCA0108439	
Sample Date		Client Info		20 Jan 2024	19 Jan 2024	
Machine Age	hrs	Client Info		0	0	
Dil Age	hrs	Client Info		0	0	
Dil Changed		Client Info		N/A	N/A	
Sample Status				ATTENTION	ABNORMAL	
CONTAMINAT	ION	method				history2
Water		WC Method	>0.2	NEG	NEG	
WEAR METAL	S	method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>200	0	3	
Chromium	ppm	ASTM D5185m	>15	<1	<1	
Nickel	ppm	ASTM D5185m	>15	0	0	
Fitanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m		0	0	
Aluminum	ppm	ASTM D5185m	>25	3	3	
ead	ppm	ASTM D5185m	>100	0	0	
Copper	ppm	ASTM D5185m	>200	0	2	
īn	ppm	ASTM D5185m	>25	0	<1	
/anadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	0	0	
Barium	ppm	ASTM D5185m	15	0	0	
lolybdenum	ppm	ASTM D5185m	15	0	0	
Nanganese	ppm	ASTM D5185m		0	0	
<i>A</i> agnesium	ppm	ASTM D5185m	50	<1	<1	
Calcium	ppm	ASTM D5185m	50	<1	<1	
hosphorus	ppm	ASTM D5185m	350	527	98	
Zinc	ppm	ASTM D5185m	100	9	4	
Sulfur	ppm	ASTM D5185m	12500	1250	0	
CONTAMINAN		method	limit/base		history1	history2
Silicon	ppm	ASTM D5185m	>50	8	▲ 111	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
FLUID CLEAN	LINESS		limit/base		history1	history2
Particles >4µm		ASTM D7647	>10000	▲ 18108 ▲ 2500	▲ 49908	
Particles >6µm		ASTM D7647	>2500	▲ 3509 184	▲ 6353	
Particles >14µm		ASTM D7647 ASTM D7647	>640 >160	184 44	229 48	
Particles >21µm		ASTM D7647 ASTM D7647	>160 >40	44	48	
Particles >38µm Particles >71µm		ASTM D7647 ASTM D7647	>40 >10	0	2	
Dil Cleanliness		ISO 4406 (c)	>20/18/16	0 ▲ 21/19/15	↓ 23/20/15	
		( )				
FLUID DEGRA			limit/base		history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	0.51	0.44	

Report Id: KRASPRMO [WUSCAR] 06071643 (Generated: 02/02/2024 06:28:15) Rev: 1

Contact/Location: Service Manager - KRASPRMO



Acid Number

Abnorma 0.20-0.00 L Jan 19/24


1.60 Abnormal

1.40 1.20 1.00 0.80 0.60 Valuer (mg KOH/d) 0.60 Bas

Ċ

# **OIL ANALYSIS REPORT**

VISUAL



	White Metal	scalar	*Visual	NONE	NONE	NONE	
	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
	Precipitate	scalar	*Visual	NONE	NONE	NONE	
	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	LIGHT	LIGHT	
	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Jan 20/24	Appearance	scalar	*Visual	NORML	NORML	NORML	
Jan,	Odor	scalar	*Visual	NORML	NORML	NORML	
°C	Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	
	Free Water	scalar	*Visual		NEG	NEG	
	FLUID PROPE	RTIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	150	<b>276.1</b>	152	
	SAMPLE IMAG	ES	method	limit/base	current	history1	history2
Jan20/24 +	Color						no image
	Bottom						no image
	GRAPHS						
	Ferrous Alloys			491,52	Particle Count		20
	10 iron			431,51	20.7		120
	E 6 - nickel			122,8	80 Severe		-24
				30,72	20-		-22
	2			7,6	Absormal		20
	724 0						-20 18
	Jan 19/24			Jan 20/24 (per 1 ml	20-		-18 406
	Non-ferrous Metal	s		salotti 41	80-		16 0
				Jan 20/24 number of particles (per 1 ml)			+20 ISO 4406:1999 Cleanliness
	8 - lead			mpe	20 -		14 SS 6
	E 6				30 -		-12 ed
	2				8-		10
	0	<u> </u>					
	Jan 19/24			Jan 20/24	2+		
	-			Ъ	0 4µ 6µ 14	μ 21μ 31	βμ 71μ
	Viscosity @ 40°C			21	Acid Number		
	250			2.1 1.1 9.10 Momber (mg KOH(g) 1.0	Abnormal		
	200 Abnormal	Statement of the local division of the local		Bu )			
	Abnormal 150 - Abnormal			rumper	Base		
	1			Z U.:	Abnormal		
	100 + +2/6				00		0/24
	Jan 1 9,24			Jan 20/24	Jan 19/24		Jan 20/24
Laboratory Sample No. Lab Number Unique Number Test Package To discuss this sample report, * - Denotes test methods that a Statements of conformity to spec	: 06071643 : 10848320 : IND 2 ( Additional T contact Customer Serv. are outside of the ISO 1	Recieved Diagnose Diagnosti ests: PrtC ice at 1-80 7025 scop	: 26 c ed : 01 f ician : Jon count ) 00-237-1369 pe of accred	Jan 2024 Feb 2024 athan Heste D. litation.	ər		E BENNETT GFIELD, MO US 65804

Contact/Location: Service Manager - KRASPRMO