OIL DIAGNOSTICS

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
PASTA [98709269 BEFORE]
Machine Id
L21 DRYER BELT LOWER WEST
Component
Gearbox
Fluid
GEAR OIL FG ISO 320 (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor. (before).

Wear
All component wear rates are normal.

Contamination
The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**PCA0114294**	PCA0071798	---
Sample Date		Client Info		**20 Jan 2024**	04 Apr 2022	---
Machine Age	hrs	Client Info		**0**	0	---
Oil Age	hrs	Client Info		**0**	0	---
Oil Changed		Client Info		**N/A**	N/A	---
Sample Status				**NORMAL**	NORMAL	---

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.2	**NEG**	NEG	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	**8**	8	---
Chromium	ppm	ASTM D5185m	>15	**<1**	0	---
Nickel	ppm	ASTM D5185m	>15	**0**	0	---
Titanium	ppm	ASTM D5185m		**0**	0	---
Silver	ppm	ASTM D5185m		**0**	0	---
Aluminum	ppm	ASTM D5185m	>25	**3**	0	---
Lead	ppm	ASTM D5185m	>100	**0**	0	---
Copper	ppm	ASTM D5185m	>200	**0**	0	---
Tin	ppm	ASTM D5185m	>25	**0**	0	---
Vanadium	ppm	ASTM D5185m		**0**	0	---
Cadmium	ppm	ASTM D5185m		**0**	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	**0**	0	---
Barium	ppm	ASTM D5185m	5	**0**	0	---
Molybdenum	ppm	ASTM D5185m	5	**0**	0	---
Manganese	ppm	ASTM D5185m		**0**	<1	---
Magnesium	ppm	ASTM D5185m	5	**<1**	0	---
Calcium	ppm	ASTM D5185m	12	**<1**	0	---
Phosphorus	ppm	ASTM D5185m	400	**499**	135	---
Zinc	ppm	ASTM D5185m	12	**4**	1	---
Sulfur	ppm	ASTM D5185m	750	**1287**	24	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	**5**	2	---
Sodium	ppm	ASTM D5185m		**0**	0	---
Potassium	ppm	ASTM D5185m	>20	**<1**	0	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	**9313**	11228	---
Particles >6µm		ASTM D7647	>2500	**2372**	2873	---
Particles >14µm		ASTM D7647	>640	**333**	251	---
Particles >21µm		ASTM D7647	>160	**97**	51	---
Particles >38µm		ASTM D7647	>40	**2**	2	---
Particles >71µm		ASTM D7647	>10	**0**	0	---
Oil Cleanliness		ISO 4406 (c)	>20/18/16	**20/18/16**	21/19/15	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	**0.61**	0.49	---

OIL ANALYSIS REPORT

OIL DIAGNOSTICS









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	---
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	---
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	---
Silt	scalar	*Visual	NONE	**NONE**	NONE	---
Debris	scalar	*Visual	NONE	**NONE**	VLITE	---
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	---
Appearance	scalar	*Visual	NORML	**NORML**	NORML	---
Odor	scalar	*Visual	NORML	**NORML**	NORML	---
Emulsified Water	scalar	*Visual	>0.2	**NEG**	NEG	---
Free Water	scalar	*Visual		**NEG**	NEG	---

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	**309**	326	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					*no image*
Bottom					*no image*

GRAPHS









Certificate L2367

Laboratory	: WearCheck USA - 501 Madison Ave., Cary, NC 27513		
Sample No.	: PCA0114294	**Recieved**	: 26 Jan 2024
Lab Number	: 06071646	**Diagnosed**	: 30 Jan 2024
Unique Number	: 10848323	**Diagnostician**	: Don Baldridge
Test Package	: IND 2 (Additional Tests: PrtCount)		

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KraftHeinz - Springfield - Plant 8311 PCA
2035 E BENNETT
SPRINGFIELD, MO
US 65804
Contact: Service Manager
T:
F: