

OIL ANALYSIS REPC

Oil Age

Water

Iron

Chromium Nickel Titanium Silver Aluminum Lead Copper Tin Vanadium Cadmium

PROCESS CHEESE [98739267] 1520 (S/N UP900139) Component

Pump Fluic

R&O OIL ISO 68 (1 LTR)

DIAGNOSIS

Recommendation

The oil change at the time of sampling has been noted. We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

| SIS REPO | ORT | Samp | le Rating Tre | end | | ISO |
|----------------------|---------|-------------|----------------------|--------------------|-------------|----------|
| 267] SAMPLE INFOF | RMATION | method | Judoza limit/base | Jan2024 Current | history1 | history2 |
| Sample Number | | Client Info | | PCA0114283 | PCA0081547 | |
| Sample Date | | Client Info | | 21 Jan 2024 | 09 Jul 2023 | |
| Machine Age | days | Client Info | | 0 | 0 | |
| Oil Age | days | Client Info | | 0 | 30 | |
| Oil Changed | | Client Info | | Changed | Changed | |
| Sample Status | | | | ABNORMAL | ABNORMAL | |
| CONTAMINA | TION | method | limit/base | current | history1 | history2 |
| Water | | WC Method | >.1 | NEG | NEG | |
| WEAR METAI | LS | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >90 | <1 | 2 | |
| Chromium | ppm | ASTM D5185m | >5 | <1 | <1 | |
| Nickel | ppm | ASTM D5185m | >5 | 0 | 0 | |
| Titanium | ppm | ASTM D5185m | >3 | <1 | 0 | |
| Silver | ppm | ASTM D5185m | >3 | 0 | 0 | |
| Aluminum | ppm | ASTM D5185m | >7 | 2 | 0 | |
| Lead | ppm | ASTM D5185m | >12 | <1 | 0 | |
| Copper | ppm | ASTM D5185m | >30 | <1 | 0 | |
| Tin | ppm | ASTM D5185m | >9 | <1 | 0 | |
| Vanadium | ppm | ASTM D5185m | | 0 | <1 | |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | 5 | 0 | 0 | |
| Barium | ppm | ASTM D5185m | 5 | 0 | 0 | |
| Molybdenum | ppm | ASTM D5185m | 5 | <1 | 0 | |
| Manganese | ppm | ASTM D5185m | | 0 | <1 | |
| Magnesium | ppm | ASTM D5185m | 5 | <1 | 2 | |
| Calcium | ppm | ASTM D5185m | 5 | 3 | 0 | |

| • | | | | | | |
|--------------|-----|-------------|------------|---------|----------|----------|
| Calcium | ppm | ASTM D5185m | 5 | 3 | 0 | |
| Phosphorus | ppm | ASTM D5185m | 100 | 238 | 33 | |
| Zinc | ppm | ASTM D5185m | 25 | 0 | 0 | |
| Sulfur | ppm | ASTM D5185m | 1500 | 560 | 0 | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >60 | 2 | 2 | |

| Sodium | ppm | ASTM D5185m | | 0 | 4 | |
|-----------------|--------|--------------|------------|-------------------|----------|----------|
| Potassium | ppm | ASTM D5185m | >20 | 2 | <1 | |
| FLUID CLEANL | INESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >1300 | A 7885 | | |
| Particles >6µm | | ASTM D7647 | >320 | 🔺 1249 | | |
| Particles >14µm | | ASTM D7647 | >80 | 21 | | |
| Particles >21µm | | ASTM D7647 | >20 | 3 | | |
| Particles >38µm | | ASTM D7647 | >4 | 0 | | |
| Particles >71µm | | ASTM D7647 | >3 | 0 | | |
| Oil Cleanliness | | ISO 4406 (c) | >17/15/13 | A 20/17/12 | | |
| FLUID DEGRAD | DATION | method | limit/base | current | history1 | history2 |

Acid Number (AN) mg KOH/g ASTM D8045 0.08

0.29

0.052 Contact/Location: Service Manager - KRASPRMO



Acid Number

Viscosity @ 40°C

0.30

(B/H0.2 E0.18

aq u 0.1

90.0 QC

0.00

80

7

(d0°C) St

65

60

OIL ANALYSIS REPORT

method


limit/base


current


history1

history2

VISUAL







31

(^B/H0,30 H0 0.24

Ē0.18

붙 0.12

0.00

Acid Nu 0.08 B

Abnorma

Acid Number

an21/7

Jan21/24



KraftHeinz - Springfield - Plant 8311 PCA Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : PCA0114283 Recieved : 30 Jan 2024 Lab Number : 01 Feb 2024 SPRINGFIELD, MO :06074665 Diagnosed : Jonathan Hester Unique Number : 10856756 Diagnostician Test Package : IND 2 (Additional Tests: PrtCount) Contact: Service Manager Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Viscosity @ 40°C

80

7! (40°C)

.70 Ba

65

60

ŝ

Contact/Location: Service Manager - KRASPRMO

21/

US 65804

T: F:

2035 E BENNETT