OIL ANALYSIS REPORT

Machine Id
426064-402205
Component
Diesel Engine
Fluid
PETRO CANADA DURON SHP 15W40 (--- GAL)

Sample Rating Trend



FUEL

DIAGNOSIS

Recommendation
We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of fuel present in the oil. Tests confirm the presence of fuel in the oil.

Fluid Condition
The BN result indicates that there is suitable alkalinity remaining in the oil. The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**GFL0109263**	GFL0048350	GFL0093549
Sample Date		Client Info		**07 Feb 2024**	29 Nov 2023	19 Nov 2023
Machine Age	hrs	Client Info		**33287**	33247	33244
Oil Age	hrs	Client Info		**40**	400	71
Oil Changed		Client Info		**Not Changd**	Changed	Not Changd
Sample Status				**ABNORMAL**	SEVERE	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.2	**NEG**	NEG	NEG
Glycol		WC Method		**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>120	**6**	3	5
Chromium	ppm	ASTM D5185m	>20	**0**	0	0
Nickel	ppm	ASTM D5185m	>5	**0**	0	0
Titanium	ppm	ASTM D5185m	>2	**45**	<1	<1
Silver	ppm	ASTM D5185m	>2	**0**	0	0
Aluminum	ppm	ASTM D5185m	>20	**<1**	2	1
Lead	ppm	ASTM D5185m	>40	**0**	<1	<1
Copper	ppm	ASTM D5185m	>330	**1**	4	4
Tin	ppm	ASTM D5185m	>15	**<1**	0	0
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	**77**	<1	<1
Barium	ppm	ASTM D5185m	0	**0**	0	0
Molybdenum	ppm	ASTM D5185m	60	**28**	57	57
Manganese	ppm	ASTM D5185m	0	**<1**	0	0
Magnesium	ppm	ASTM D5185m	1010	**671**	818	842
Calcium	ppm	ASTM D5185m	1070	**1349**	978	953
Phosphorus	ppm	ASTM D5185m	1150	**1008**	914	947
Zinc	ppm	ASTM D5185m	1270	**1195**	1064	1085
Sulfur	ppm	ASTM D5185m	2060	**3471**	2876	2731

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**4**	3	3
Sodium	ppm	ASTM D5185m		**1**	0	0
Potassium	ppm	ASTM D5185m	>20	**<1**	3	2
Fuel	%	ASTM D3524	>3.0	▲ **3.7**	⬢ 5.7	⬢ 6.0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>4	**0.2**	0.3	0.3
Nitration	Abs/cm	*ASTM D7624	>20	**5.2**	4.6	4.9
Sulfation	Abs/.1mm	*ASTM D7415	>30	**18.1**	17.2	17.6

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	**13.1**	12.2	12.5
Base Number (BN)	mg KOH/g	ASTM D2896	9.8	**8.7**	8.6	8.7

OIL ANALYSIS REPORT

Fuel Dilution



Base Number



Viscosity @ 100°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.4	**13.1**	12.4	12.5

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : GFL0109263
Lab Number : 06084270
Unique Number : 10871715
Test Package : FLEET (Additional Tests: PercentFuel)

Received : 08 Feb 2024
Tested : 09 Feb 2024
Diagnosed : 09 Feb 2024 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

GFL Environmental - 891 - Oklahoma City Hauling
1001 South Rockwell
Oklahoma City, OK
US 73128
Contact: Andy Smith
andrew.smith@gflenv.com
T: (405)306-1651
F: