


OIL ANALYSIS REPORT

Galy Line [Galv Line] 650250-HOT BRIDLE ROLL # 2

Gearbox

PETRO CANADA ENDURATEX EP 220 (--- GAL)



Sample Rating Trend



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


GAL)		Aug2021	Feb2022 Aug2022	Feb2023 Jul2023	Feb 2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0112962	PCA0107663	PCA0101472
Sample Date		Client Info		13 Feb 2024	20 Nov 2023	01 Jul 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water	1011	WC Method	>0.2	NEG	NEG	NEG
WEAR METAL	C					
	5	method	limit/base	current	history1	history2
PQ		ASTM D8184		13		12
Iron	ppm	ASTM D5185m		11	9	12
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	<1	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	0	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	19	18	17
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m	0	0	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	<1	<1
Calcium	ppm	ASTM D5185m	0	6	8	7
Phosphorus	ppm	ASTM D5185m	270	271	262	257
Zinc	ppm	ASTM D5185m	0	19	16	25
Sulfur	ppm	ASTM D5185m	11200	9491	8961	10172
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	12	12	10
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	0	<1
FLUID DEGRA	OITAC	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.88	0.81	0.93



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROP	EULIES	method			riistory i	nistory∠
Visc @ 40°C	cSt	ASTM D445	220	223	223	222

SAMP	LE IN	1AGES

Color

Bottom



GRAPHS PQ Ferrous Alloys 220 160 140 2 120 · 100 Non-ferrous Metals Viscosity @ 40°C Acid Number 00.1 08.0 08.0 240 (2-0+) 220 Ē 0.60 흔 0.40 툴 0.20 0.00 Acid 180





Certificate L2367

Laboratory Sample No. Lab Number : 06088317 Unique Number : 10875762

Test Package : PLANT

: PCA0112962

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

Tested Diagnosed

Feb1/23 -

Jul1/23

: 13 Feb 2024 : 14 Feb 2024

Feb13/24

: 14 Feb 2024 - Wes Davis

SDI - Steel DynamicsInc. - Heartland

455 West Industrial Drive

Terre Haute, IN

US 47802 Contact: BRAD ELLIS

brad.ellis@steeldynamics.com T:

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: