OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL

Area
(YA117743)
Machine Id
2524
Component
Diesel Engine
Fluid
PETRO CANADA DURON SHP 15W40 (8 GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**GFL0090002**	GFL0099810	GFL0080553
Sample Date		Client Info		**03 Feb 2024**	22 Nov 2023	13 Oct 2023
Machine Age	hrs	Client Info		**27232**	42982	79952
Oil Age	hrs	Client Info		**600**	0	79952
Oil Changed		Client Info		**Changed**	Not Changd	Changed
Sample Status				**NORMAL**	NORMAL	NORMAL

CONTAMINATION	method	limit/base	current	history1	history2
Fuel	WC Method	>3.0	**<1.0**	<1.0	<1.0
Water	WC Method	>0.2	**NEG**	NEG	NEG
Glycol	WC Method		**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>165	**25**	3	15
Chromium	ppm	ASTM D5185m	>5	**2**	<1	<1
Nickel	ppm	ASTM D5185m	>4	**<1**	0	<1
Titanium	ppm	ASTM D5185m	>2	**<1**	0	0
Silver	ppm	ASTM D5185m	>2	**<1**	0	0
Aluminum	ppm	ASTM D5185m	>20	**2**	1	0
Lead	ppm	ASTM D5185m	>150	**2**	0	2
Copper	ppm	ASTM D5185m	>90	**2**	<1	2
Tin	ppm	ASTM D5185m	>5	**1**	0	<1
Vanadium	ppm	ASTM D5185m		**<1**	0	0
Cadmium	ppm	ASTM D5185m		**<1**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	**5**	4	2
Barium	ppm	ASTM D5185m	0	**0**	0	2
Molybdenum	ppm	ASTM D5185m	60	**62**	61	64
Manganese	ppm	ASTM D5185m	0	**<1**	0	<1
Magnesium	ppm	ASTM D5185m	1010	**964**	942	879
Calcium	ppm	ASTM D5185m	1070	**1107**	1089	1076
Phosphorus	ppm	ASTM D5185m	1150	**1079**	1014	1028
Zinc	ppm	ASTM D5185m	1270	**1239**	1234	1181
Sulfur	ppm	ASTM D5185m	2060	**3668**	3573	2897

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	**11**	2	7
Sodium	ppm	ASTM D5185m		**3**	<1	3
Potassium	ppm	ASTM D5185m	>20	**28**	1	7

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>7.5	**1**	0.4	1
Nitration	Abs/cm	*ASTM D7624	>20	**11.3**	4.8	10.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	**22.9**	17.8	21.9

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	**19.3**	13.0	18.3
Base Number (BN)	mg KOH/g	ASTM D2896	9.8	**7.6**	9.4	7.1

OIL ANALYSIS REPORT

Base Number



Viscosity @ 100°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.4	**13.6**	13.9	13.8

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 100°C



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : GFL0090002
Lab Number : 06088564
Unique Number : 10876009
Test Package : FLEET

Received : 14 Feb 2024
Tested : 19 Feb 2024
Diagnosed : 19 Feb 2024 - Wes Davis

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

GFL Environmental - 018 - Fayetteville
4621 Marracco Drive
Hope Mills, NC
US 28348
Contact: Robert Carter
robert.carter@gflenv.com
T: (910)596-1170
F: