


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



L-5 SAT

Component Gearbox

PETRO CANADA ENDURATEX EP 460 (26 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL) 0x2019 0x2021 Feb2024								
SAMPLE INFOR	RMATION	method	limit/base	current	history1	history2		
Sample Number		Client Info		PCA0030544	PCA0030574	PCAI27682		
Sample Date		Client Info		16 Feb 2024	21 Dec 2021	21 Oct 2019		
Machine Age	hrs	Client Info		0	0	0		
Oil Age	hrs	Client Info		0	0	0		
Oil Changed		Client Info		N/A	N/A	N/A		
Sample Status				NORMAL	ATTENTION	ABNORMAL		
CONTAMINAT	ΓΙΟΝ	method	limit/base	current	history1	history2		
Water		WC Method	>0.2	NEG	NEG	NEG		
WEAR METAL	_S	method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185m	>200	5	5	22		
Chromium	ppm	ASTM D5185m	>15	<1	<1	<1		
Nickel	ppm	ASTM D5185m	>15	0	0	<1		
Titanium	ppm	ASTM D5185m		<1	<1	2		
Silver	ppm	ASTM D5185m		0	<1	0		
Aluminum	ppm	ASTM D5185m	>25	2	2	<1		
Lead	ppm	ASTM D5185m	>100	0	<1	0		
Copper	ppm	ASTM D5185m	>200	<1	<1	1		
Tin	ppm	ASTM D5185m	>25	0	<1	0		
Antimony	ppm	ASTM D5185m	>5		<1	0		
Vanadium	ppm	ASTM D5185m		0	0	0		
Cadmium	ppm	ASTM D5185m		0	0	0		
ADDITIVES		method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m	55	60	54	5		
Barium	ppm	ASTM D5185m	0	0	0	0		
Molybdenum	ppm	ASTM D5185m	0	0	0	0		
Manganese	ppm	ASTM D5185m	0	0	<1	<1		
Magnesium	ppm	ASTM D5185m	2	<1	0	0		
Calcium	ppm	ASTM D5185m	6	1	<1	1		
Phosphorus	ppm	ASTM D5185m	240	263	239	492		
Zinc	ppm	ASTM D5185m	3	0	0	13		
Sulfur	ppm	ASTM D5185m	10310	6720	5199	780		
CONTAMINA	NTS	method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>50	8	5	8		
Sodium	ppm	ASTM D5185m		0	0	<1		
Potassium	ppm	ASTM D5185m	>20	2	<1	<1		
FLUID DEGRA	DATION	method	limit/base	current	history1	history2		

Acid Number (AN)

mg KOH/g ASTM D8045 0.5


0.442

0.45


0.750



OIL ANALYSIS REPORT



VISUAL White Metal scal Yellow Metal scal Precipitate scal Silt scal Debris scal Sand/Dirt scal Appearance scal	lar *Visual lar *Visual lar *Visual lar *Visual	NONE NONE NONE NONE NONE NONE	NONE NONE NONE NONE	history1 LIGHT NONE NONE	NONE NONE NONE
Yellow Metal scale Precipitate scale Silt scale Debris scale Sand/Dirt scale scale scale Sand/Dirt scale sca	lar *Visual lar *Visual lar *Visual lar *Visual	NONE NONE	NONE NONE	NONE NONE	NONE
Precipitate scal Silt scal Debris scal Sand/Dirt scal	lar *Visual lar *Visual lar *Visual	NONE NONE	NONE	NONE	
Silt scal Debris scal Sand/Dirt scal	lar *Visual lar *Visual	NONE			NONE
Debris sca Sand/Dirt sca	lar *Visual		NONE	NIGNIE	
Sand/Dirt sca		NONE	ITOITE	NONE	NONE
00.10.	lar *Visual	INOINL	NONE	VLITE	▲ MODER
Appearance scal	iai viodai	NONE	NONE	NONE	NONE
L L	lar *Visual	NORML	NORML	NORML	NORML
Odor sca	lar *Visual	NORML	NORML	NORML	NORML
Emulsified Water scal	lar *Visual	>0.2	NEG	NEG	NEG
Free Water sca	lar *Visual		NEG	NEG	NEG
FLUID PROPERTIE	ES method	limit/base	current	history1	history2
Visc @ 40°C cSt	ASTM D445	452	467	460	392
SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					







Certificate L2367

Laboratory Sample No.

: PCA0030544 Lab Number : 06096332 Unique Number : 10889185 Test Package : IND 2

Bottom

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 21 Feb 2024 **Tested** Diagnosed

: 22 Feb 2024 : 22 Feb 2024 - Wes Davis

CERTAINTEED CORP 701 E WASHINGTON ST

JACKSON, MI US 49203

Contact: SIDNEY CHAPPELL

To discuss this sample report, contact Customer Service at 1-800-237-1369.

SIDNEY.A.CHAPPELL@SAINT-GOBAIN.COM T:

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (517)787-8974