




# PROBLEM SUMMARY

Sample Rating Trend




WATER



Area  
**Process Cheese [98843093 BEFORE]**  
 Machine Id  
**BLENDER 2**  
 Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (--- GAL)**

## COMPONENT CONDITION SUMMARY

▲ Water (KF)



## RECOMMENDATION

We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. We recommend you service the filters on this component. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	ATTENTION
Water	%	ASTM D6304	>0.2	▲ <b>1.15</b>	---	---
ppm Water	ppm	ASTM D6304	>2000	▲ <b>11500</b>	---	---
Debris	scalar	*Visual	NONE	▲ <b>HEAVY</b>	NONE	NONE
Emulsified Water	scalar	*Visual	>0.2	▲ <b>0.2%</b>	NEG	NEG

Customer Id: KRASPRMO  
 Sample No.: PCA0117985  
 Lab Number: 06101583  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Feb 29 2024	?	We recommend you service the filters on this component.
Resample	MISSED	Feb 29 2024	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.
Check Water Access	MISSED	Feb 29 2024	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

### 19 Dec 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 20 Sep 2023 Diag: Don Baldrige

ISO



The oil filtered at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



### 02 Aug 2023 Diag: Doug Bogart

WATER






We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. There is too much water present in this sample to perform a particle count. All component wear rates are normal. Excessive free water present. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report






# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ HEAVY	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● MILKY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	316	313	309

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0117985  
**Lab Number** : 06101583  
**Unique Number** : 10899813  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**KraftHeinz - Springfield - Plant 8311 PCA**  
 2035 E BENNETT  
 SPRINGFIELD, MO  
 US 65804  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: