


# **OIL ANALYSIS REPORT**

# Temper Mill [Temper Mill] 230235-DELIVERY COIL CAR

**Hydraulic System** 

PETRO CANADA HYDREX AW 46 (--- GAL)





# **DIAGNOSIS**

### Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

# Wear

All component wear rates are normal.

### Contamination

Moderate concentration of visible dirt/debris present in the oil.


### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Nov2021 Feb20	022 May2022 Aug2022 Nov20	022 Feb 2023 May 2023 Aug 2023 Dec 2	023 Feb2024	
SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0112948	PCA0107686	PCA0101468
Sample Date		Client Info		26 Feb 2024	26 Dec 2023	14 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS	}	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	6	1	2
Chromium	ppm	ASTM D5185m	>20	0	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	0	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	<1	2	<1
Tin	ppm	ASTM D5185m	>20	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0	0
Magnesium	ppm	ASTM D5185m	0	1	<1	3
Calcium	ppm	ASTM D5185m	50	59	55	52
Phosphorus	ppm	ASTM D5185m	330	349	324	340
Zinc	ppm	ASTM D5185m	430	466	426	420
Sulfur	ppm	ASTM D5185m	760	917	1009	1683
CONTAMINANT	ΓS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	1	0	<1
Sodium	ppm	ASTM D5185m	7.0	0	<1	<1
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304		NEG	NEG	NEG
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000		3573	4046
Particles >6µm		ASTM D7647	>1300		480	833
Particles >14μm		ASTM D7647	>1600		33	45
Particles >21μm		ASTM D7647	>40		10	8
Particles >38µm		ASTM D7647	>10		1	0
Particles >71µm		ASTM D7647	>3		1	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14		19/16/12	19/17/13
FLUID DEGRAD	ΔΤΙΩΝ	` '	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.70	0.35	0.29	0.39



# **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.4	45.6	46.1	47.9
SAMPLE IMAGES		method	limit/base	current	history1	history2


Color










## **GRAPHS**













Certificate L2367

Laboratory Sample No. Lab Number : 06102448 Unique Number : 10900678

Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0112948

Received **Tested** 

: 27 Feb 2024 : 29 Feb 2024 Diagnosed : 29 Feb 2024 - Don Baldridge

SDI - Steel DynamicsInc. - Heartland

455 West Industrial Drive Terre Haute, IN US 47802

Contact: BRAD ELLIS brad.ellis@steeldynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: