

OIL ANALYSIS REPORT

Sample Rating Trend





ALBERT LEA Machine Id Unit 05 DB010105E

Component

Natural Gas Engine

PETRO CANADA DURON MONOGRADE HD 40W (350 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: 113 gallons of lube oil added this month.)

Wear

All component wear rates are normal.

Contamination

Light fuel dilution occurring. No other contaminants were detected in the oil.


Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Nov2022 Apr2023 Sep2023	Jan 2024	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0106491	PCA0106488	PCA0106487
Sample Date		Client Info		29 Feb 2024	25 Jan 2024	30 Dec 2023
Machine Age	hrs	Client Info		2323	1872	1400
Oil Age	hrs	Client Info		2323	1872	1400
Oil Changed		Client Info		Not Changd	Oil Added	Not Changd
Sample Status				MARGINAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	5	11	7
Chromium	ppm	ASTM D5185m	>4	<1	<1	0
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	2	1
Lead	ppm	ASTM D5185m	>30	<1	<1	<1
Copper	ppm	ASTM D5185m	>35	3	4	3
Tin	ppm	ASTM D5185m	>4	0	0	<1
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
	le le					
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	2	<1
Barium	ppm	ASTM D5185m		0	5	0
Molybdenum	ppm	ASTM D5185m		1	1	2
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		954	1314	924
Calcium	ppm	ASTM D5185m		1018	1352	1018
Phosphorus	ppm	ASTM D5185m		1048	1504	1015
Zinc	ppm	ASTM D5185m		1361	1831	1304
Sulfur	ppm	ASTM D5185m		3098	4424	2938
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	6	6	4
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	1	1	0
Fuel	%	ASTM D3524	>4.0	<u> </u>	1.9	1.9
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	4.1	4.0	3.9
Sulfation	Abs/.1mm	*ASTM D7415	>30	13.6	13.2	13.0
FLUID DEGRAD	OATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	7.2	7.0	6.7
Acid Number (AN)	mg KOH/g	ASTM D8045	20	1.59	1.43	1.48
Base Number (BN)	mg KOH/g	ASTM D8043	8.5	8.41	8.10	8.12
Dase Mullipel (DIV)	my NOTIFY	AOTIVI DZ030	0.0	0.41	0.10	0.12



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: PCA0106491 : 06108846 Unique Number: 10912343

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received **Tested** Diagnosed

: 05 Mar 2024 : 07 Mar 2024

: 07 Mar 2024 - Sean Felton

Magellan Midstream LP - Albert Lea 11406 755th Avenue Glenville, MN

US 56036 Contact: Shawn Duren

shawn.duren@magellanlp.com T: (641)231-6666

Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel) Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: