




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
Grinding Room
Machine Id
main plant hydraulics
Component
Hydraulic System
Fluid
MOBIL DTE 25 (--- GAL)

DIAGNOSIS

- Recommendation**
No corrective action is recommended at this time. Resample at the next service interval to monitor.
- Wear**
The copper level is abnormal. The iron level is abnormal.
- Contamination**
The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.
- Fluid Condition**
The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0113551	PCA0099616	PCA0092061
Sample Date	Client Info	14 Feb 2024	05 Sep 2023	30 May 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	MARGINAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.05	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >20	▲ 29	▲ 35	▲ 35
Chromium	ppm ASTM D5185m >20	0	0	0
Nickel	ppm ASTM D5185m >20	0	0	0
Titanium	ppm ASTM D5185m	0	<1	<1
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >20	<1	0	1
Lead	ppm ASTM D5185m >20	0	<1	0
Copper	ppm ASTM D5185m >20	▲ 118	▲ 129	▲ 116
Tin	ppm ASTM D5185m >20	<1	0	0
Vanadium	ppm ASTM D5185m	0	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	<1	1	2
Manganese	ppm ASTM D5185m	0	<1	<1
Magnesium	ppm ASTM D5185m	0	0	0
Calcium	ppm ASTM D5185m	60	70	77
Phosphorus	ppm ASTM D5185m	359	391	396
Zinc	ppm ASTM D5185m	409	455	468
Sulfur	ppm ASTM D5185m	1120	1439	1486

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >15	<1	1	<1
Sodium	ppm ASTM D5185m	3	3	2
Potassium	ppm ASTM D5185m >20	12	17	21






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	762	375	174
Particles >6µm	ASTM D7647 >2500	208	58	61
Particles >14µm	ASTM D7647 >640	10	3	10
Particles >21µm	ASTM D7647 >160	4	1	4
Particles >38µm	ASTM D7647 >40	0	0	0
Particles >71µm	ASTM D7647 >10	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/16	17/15/10	16/13/9	15/13/10

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045	0.38	0.30	0.39


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	44.2	45.5	45.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0113551
Lab Number : 06110121
Unique Number : 10913618
Test Package : IND 2

Received : 06 Mar 2024
Tested : 07 Mar 2024
Diagnosed : 08 Mar 2024 - Don Baldrige

KraftHeinz - New Ulm - Plant 8302
 2525 S BRIDGE STREET
 NEW ULM, MN
 US 56073
 Contact: RYAN SCHMID
 ryan.schmid@kraftheinz.com
 T: (507)568-0338
 F: (507)354-7927

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)