


Area
PLANT 1 [907308372]
 Machine Id
RC-3 PLANT 1 (S/N MK6B1641)
 Component
Refrigeration Compressor
 Fluid
PETRO CANADA REFLO XL SYNTHETIC BLEND (110 GAL)



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0103380	PCA0068398	PCA0071496
Sample Date	Client Info	21 Feb 2024	25 Jul 2023	13 Feb 2023
Machine Age	hrs	24095	19289	15811
Oil Age	hrs	0	0	0
Oil Changed	Client Info	Not Changed	Not Changed	Not Changed
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >8	0	1	<1
Chromium	ppm ASTM D5185m >2	0	0	0
Nickel	ppm ASTM D5185m	0	0	0
Titanium	ppm ASTM D5185m	0	0	0
Silver	ppm ASTM D5185m >2	0	<1	0
Aluminum	ppm ASTM D5185m >3	0	0	<1
Lead	ppm ASTM D5185m >2	<1	0	<1
Copper	ppm ASTM D5185m >8	0	0	0
Tin	ppm ASTM D5185m >4	0	0	0
Vanadium	ppm ASTM D5185m	<1	0	0
Cadmium	ppm ASTM D5185m	<1	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	0	0	0
Magnesium	ppm ASTM D5185m	0	0	0
Calcium	ppm ASTM D5185m	0	<1	2
Phosphorus	ppm ASTM D5185m	0	0	5
Zinc	ppm ASTM D5185m	0	0	3
Sulfur	ppm ASTM D5185m	857	1369	1314

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >15	<1	0	<1
Sodium	ppm ASTM D5185m	<1	0	0
Potassium	ppm ASTM D5185m >20	1	<1	0
Water	% ASTM D6304 >0.01	0.00	0.003	0.003
ppm Water	ppm ASTM D6304 >100	0	37.9	35.8

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 23637	▲ 34672	▲ 37526
Particles >6µm	ASTM D7647 >2500	● 4424	▲ 7858	▲ 10032
Particles >14µm	ASTM D7647 >320	134	81	▲ 405
Particles >21µm	ASTM D7647 >80	20	8	78
Particles >38µm	ASTM D7647 >20	0	0	2
Particles >71µm	ASTM D7647 >4	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 22/19/14	▲ 22/20/14	▲ 22/21/16

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D974 0.1	0.014	0.013	0.015

OIL ANALYSIS REPORT


▲ Particle Trend




Water (KF)




Acid Number



Water (KF)




Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	LIGHT	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	59.3	63.2	59.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0103380 **Received** : 08 Mar 2024
Lab Number : 06112950 **Tested** : 11 Mar 2024
Unique Number : 10916447 **Diagnosed** : 11 Mar 2024 - Don Baldrige

MCCAIN FOODS
 319 RICHARDSON RD
 EASTON, ME
 US 04740
 Contact: ROCKY DEWITT
 rocky.dewitt@mccain.com
 T: (207)488-1251
 F: (207)488-1249

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)