


# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**JOHN DEERE 350P 2517**  
 Component  
**Diesel Engine**  
 Fluid  
**DIESEL ENGINE OIL SAE 40 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

Metal levels are typical for a new component breaking in.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is acceptable for the time in service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>PCA0064494</b>	---	---
Sample Date	Client Info		<b>09 Mar 2024</b>	---	---
Machine Age	hrs	Client Info	<b>1744</b>	---	---
Oil Age	hrs	Client Info	<b>1744</b>	---	---
Oil Changed	Client Info		<b>Changed</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>2.1	<b>&lt;1.0</b>	---	---
Water	WC Method	>0.21	<b>NEG</b>	---	---
Glycol	WC Method		<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >51	<b>20</b>	---	---
Chromium	ppm	ASTM D5185m >11	<b>&lt;1</b>	---	---
Nickel	ppm	ASTM D5185m >5	<b>2</b>	---	---
Titanium	ppm	ASTM D5185m	<b>0</b>	---	---
Silver	ppm	ASTM D5185m >3	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m >31	<b>2</b>	---	---
Lead	ppm	ASTM D5185m >26	<b>0</b>	---	---
Copper	ppm	ASTM D5185m >26	<b>31</b>	---	---
Tin	ppm	ASTM D5185m >4	<b>&lt;1</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	---	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 250	<b>29</b>	---	---
Barium	ppm	ASTM D5185m 10	<b>0</b>	---	---
Molybdenum	ppm	ASTM D5185m 100	<b>80</b>	---	---
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Magnesium	ppm	ASTM D5185m 450	<b>884</b>	---	---
Calcium	ppm	ASTM D5185m 3000	<b>1097</b>	---	---
Phosphorus	ppm	ASTM D5185m 1150	<b>953</b>	---	---
Zinc	ppm	ASTM D5185m 1350	<b>1137</b>	---	---
Sulfur	ppm	ASTM D5185m 4250	<b>2803</b>	---	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >22	<b>4</b>	---	---
Sodium	ppm	ASTM D5185m >216	<b>2</b>	---	---
Potassium	ppm	ASTM D5185m >20	<b>0</b>	---	---



## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >3	<b>0.4</b>	---	---
Nitration	Abs/cm	*ASTM D7624 >20	<b>7.2</b>	---	---
Sulfation	Abs.1mm	*ASTM D7415 >30	<b>19.6</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs.1mm	*ASTM D7414 >25	<b>15.5</b>	---	---
Base Number (BN)	mg KOH/g	ASTM D2896 8.5	<b>8.7</b>	---	---









# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.21	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	<b>13.8</b>	---

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0064494      **Received** : 15 Mar 2024  
**Lab Number** : **06120078**      **Tested** : 19 Mar 2024  
**Unique Number** : 10928911      **Diagnosed** : 19 Mar 2024 - Don Baldrige  
**Test Package** : MOB 1 ( Additional Tests: TBN )

**D-CONSTRUCTION**  
 1488 S BROADWAY  
 COAL CITY, IL  
 US 60416

Contact: J. MASCOLO  
 J.MASCOLO@DCONSTRUCTION.COM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (815)518-3150

F: