


# **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



# GRATE 2

Component Gearbox

### **QUAKER CHEMICAL QUINTOLUBRIC 888-4**

## DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


46 ( GAL)		Nov2022	Feb2023	May2023 Oct2023	Mar2024	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0083669	PCA0083676	PCA0083631
Sample Date		Client Info		17 Mar 2024	03 Oct 2023	15 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	96	96	95
Chromium	ppm	ASTM D5185m	>15	7	7	7
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	2	0
Lead	ppm	ASTM D5185m	>100	0	6	0
Copper	ppm	ASTM D5185m	>200	<1	<1	0
Tin	ppm	ASTM D5185m	>25	318	311	271
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		1	1	1
Magnesium	ppm	ASTM D5185m		<1	1	0
Calcium	ppm	ASTM D5185m		2	4	4
Phosphorus	ppm	ASTM D5185m		143	109	103
Zinc	ppm	ASTM D5185m		50	51	34
Sulfur	ppm	ASTM D5185m		776	650	590
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	3	4	1
Sodium	ppm	ASTM D5185m		5	6	1
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.2	NEG	NEG	NEG
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	2043	1146	5497
Particles >6µm		ASTM D7647	>5000	858	249	663
Particles >14μm		ASTM D7647	>640	160	23	52
Particles >21μm		ASTM D7647		59	7	20
Particles >38μm		ASTM D7647	>40	5	0	1
Particles >71μm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	18/17/14	17/15/12	20/17/13
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		2.49	1.96	1.94




# **OIL ANALYSIS REPORT**









VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPI	ERITES	method		history1	history2
Visc @ 40°C	cSt	ASTM D445	49.2	49.2	49.4

SAMPLE IMAGES	metnoa	limit/c
Color		





GRAPHS	8							
Ferrous All				Particle	Count			20
150 representation iron				491,520 Severe 122,880				26
50				30,720 Abnormal	1			-22
U	23 23	23		7,680	1			20 58
Nov8/22	Feb22/23	Oct3/23	Mar17/24	1,920	`*\ <u>`</u>			18 18
Non-ferrou	_		- to	480-	/			16 Clea
300 - coppe	37	danaanaanaanaanaa	Mar17/24	120-		\		180 4406:1999 Cleanliness Code
E 200			ê	30-		1		-12 G
100				8-			/	10
	Feb22/23	Oct3/23 -	Mar17/24	2-			/	-8
'		ŏ	Mar		μ 14μ	21μ	38μ	71 <sub>µ</sub> 6
Viscosity @	9 40°C 			Acid Nu	ımber			
Abnormal	 	<u> </u>	-	NON POOR				
Abnormal				DU.2.00				
45	<u> </u>			Acid Number (mg KOH/g) 000 0 000 000 000 000 000 000 000 000				
Nov8/22 +	Feb22/23 -	Oct3/23 -	Mar17/24	A 8.00 8.00 8.00 8.00 8.00 8.00 8.00 8.0	Feb22/23 -	May15/23 -	Oct3/23 -	Mar17/24
N	Reb	ŏ	Mar	N.	湿	Мау	ŏ	Mar



Laboratory Sample No. Unique Number: 10929666

Lab Number : 06120833

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0083669

Received **Tested** Diagnosed

: 18 Mar 2024 : 20 Mar 2024

: 20 Mar 2024 - Don Baldridge

WHEELABRATOR 100 SALEM TURNPIKE SAUGUS, MA US 01906 Contact:

Test Package: IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (518)312-1460

F: