


## **OIL ANALYSIS REPORT**





### DIAGNOSIS

#### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

Moderate concentration of visible dirt/debris present in the oil.

#### Fluid Condition


The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0120345		
Sample Date		Client Info		19 Mar 2024		
	hrs	Client Info		52209		
5	hrs	Client Info		0		
Oil Changed	1110	Client Info		N/A		
Sample Status				ABNORMAL		
		una atta a al	line it /le e e e			
CONTAMINATIO		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>10	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
	ppm	ASTM D5185m	>10	0		
	ppm	ASTM D5185m	>10	0		
	ppm	ASTM D5185m	>75	9		
	ppm	ASTM D5185m	>10	0		
	ppm	ASTM D5185m		0		
	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	1		
Barium	ppm	ASTM D5185m	5	0		
Molybdenum	ppm	ASTM D5185m	5	<1		
	ppm	ASTM D5185m		0		
	ppm	ASTM D5185m	25	8		
-	ppm	ASTM D5185m	200	103		
	ppm	ASTM D5185m	300	337		
	ppm	ASTM D5185m	370	421		
	ppm	ASTM D5185m	2500	1133		
CONTAMINANT	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>20	2		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
	scalar	*Visual	NONE	NONE		
Precipitate				NONE		
	scalar	*Visual	NONE	NONE		
Silt	scalar scalar	*Visual *Visual	NONE			
Silt Debris						
Silt Debris Sand/Dirt	scalar	*Visual	NONE			
Silt Debris Sand/Dirt Appearance	scalar scalar	*Visual *Visual	NONE NONE	MODER NONE		
Silt Debris Sand/Dirt Appearance Odor	scalar scalar scalar	*Visual *Visual *Visual	NONE NONE NORML	MODER NONE NORML		
Silt Debris Sand/Dirt Appearance Odor Emulsified Water	scalar scalar scalar scalar	*Visual *Visual *Visual *Visual	NONE NORML NORML	MODER NONE NORML NORML	 	

Page 1 of 2



# **OIL ANALYSIS REPORT**



	FLUID PROPE	RHES	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445	32	31.2			
	SAMPLE IMAG	GES	method	limit/base	current	history1	history2	
65	Color				no image	no image	no image	
Mar19,24	Bottom				no image	no image	no image	
	GRAPHS						1	
	Ferrous Alloys	ls		Mar19/24				
	G 34 G 32 Base Abnormal 28+							
	26 + + + 2/61 use W			Mar19/24 +				
Laboratory Sample No. Lab Number Unique Number Test Package	10939429 Diagnosed : 25 Mar 2024 - Don Baldridge					COSTYS ENERGY SERVICES 2329 S MAIN S <sup></sup> MANSFIELD, P/ US 1693 Contact: CJ MARTIN cmartin@costysenergy.con		

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)