


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id **744006**

Component **Natural Gas Engine**

PETRO CANADA DURON GEO LD 15W40 (

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

(LTR)		Jun2021 Aug	2021 Dec2021 Mar2022 Apr2	022 Oct2022 Mar2023 Sep2023 Dec2	023 Mar ² 024	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		GFL0115495	GFL0094235	GFL0089735
Sample Date		Client Info		22 Mar 2024	08 Dec 2023	07 Sep 2023
Machine Age	hrs	Client Info		23236	22655	22187
Oil Age	hrs	Client Info		581	468	944
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	20	5	4
Chromium	ppm	ASTM D5185m	>4	0	<1	<1
Nickel	ppm	ASTM D5185m	>2	<1	<1	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	1	2
Lead	ppm	ASTM D5185m	>30	1	<1	0
Copper	ppm	ASTM D5185m	>35	<1	<1	<1
Tin	ppm	ASTM D5185m	>4	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	4	26	27
Barium	ppm	ASTM D5185m	5	0	11	0
Molybdenum	ppm	ASTM D5185m	50	59	50	49
Manganese	ppm	ASTM D5185m	0	<1	<1	1
Magnesium	ppm	ASTM D5185m	560	873	543	615
Calcium	ppm	ASTM D5185m	1510	1050	1468	1591
Phosphorus	ppm	ASTM D5185m	780	1040	757	806
Zinc	ppm	ASTM D5185m	870	1228	913	1027
Sulfur	ppm	ASTM D5185m	2040	3374	2723	3180
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	3	3	3
Sodium	ppm	ASTM D5185m		17	4	4
Potassium	ppm	ASTM D5185m	>20	10	3	2
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		1.5	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	10.4	8.4	8.6
Sulfation	Abs/.1mm	*ASTM D7415	>30	20.6	18.5	17.5
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	16.6	16.1	14.7
Base Number (BN)	mg KOH/g	ASTM D2896		8.7	7.5	7.9
(= 1)	39					



OIL ANALYSIS REPORT






VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPERTIES		method				history2
Visc @ 100°C	cSt	ASTM D445	15.1	12.7	14.5	14.6


GRAPHS


Ferrous Alloys















Laboratory Sample No.

: GFL0115495 Lab Number : 06129125 Unique Number : 10943276

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 26 Mar 2024 **Tested** : 27 Mar 2024

Diagnosed : 28 Mar 2024 - Don Baldridge

GFL Environmental - 882 - Gainesville

5002 SW 41st Blvd Gainesville, FL US 32608

Contact: ROBERT CLARK robert.clark@gflenv.com

Test Package : FLEET Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: