


OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Area
Irvington
 Machine Id
Unit 03 DB060103E
 Component
Natural Gas Engine
 Fluid
PETRO CANADA DURON MONOGRADE HD 40W (250 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: Top Up Amount: 0 GAL)

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0105161	PCA0105153	PCA0105164
Sample Date	Client Info		25 Mar 2024	01 Feb 2024	04 Jan 2024
Machine Age	hrs	Client Info	24598	24598	24515
Oil Age	hrs	Client Info	24598	24598	24515
Oil Changed		Client Info	Oil Added	Oil Added	Oil Added
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	5	3	6
Chromium	ppm	ASTM D5185m >4	0	<1	<1
Nickel	ppm	ASTM D5185m >2	0	0	<1
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	<1	2	2
Lead	ppm	ASTM D5185m >30	<1	0	2
Copper	ppm	ASTM D5185m >35	1	<1	2
Tin	ppm	ASTM D5185m >4	<1	0	1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<1	<1	1
Barium	ppm	ASTM D5185m	0	5	0
Molybdenum	ppm	ASTM D5185m	1	<1	3
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	907	938	1385
Calcium	ppm	ASTM D5185m	1041	1064	1527
Phosphorus	ppm	ASTM D5185m	1153	1158	1529
Zinc	ppm	ASTM D5185m	1328	1293	1918
Sulfur	ppm	ASTM D5185m	3574	3456	5274

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	13	2	4
Sodium	ppm	ASTM D5185m	2	0	0
Potassium	ppm	ASTM D5185m >20	<1	1	1
Fuel	%	ASTM D3524 >4.0	1.7	1.6	1.9





INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0.1	0
Nitration	Abs/cm	*ASTM D7624 >20	3.9	3.9	3.9
Sulfation	Abs/.1mm	*ASTM D7415 >30	13.3	13.1	13.0

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	6.8	6.9	6.9
Acid Number (AN)	mg KOH/g	ASTM D8045	1.76	1.50	1.64
Base Number (BN)	mg KOH/g	ASTM D2896 8.5	8.40	8.14	8.41









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	14.4	13.5	13.4	13.4

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0105161 **Received** : 26 Mar 2024
Lab Number : 06129542 **Tested** : 29 Mar 2024
Unique Number : 10943693 **Diagnosed** : 29 Mar 2024 - Don Baldrige
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

Magellan Midstream LP - Omaha
 9405 Bennington Road
 Omaha, NE
 US 68122
 Contact: Zach Jones
 zach.jones@magellanlp.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: