


# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**Process Cheese [98913379]**  
 Machine Id  
**BLENDER 2**  
 Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA0120249</b>	PCA0117971	PCA0117970
Sample Date	Client Info	<b>24 Mar 2024</b>	12 Mar 2024	09 Mar 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>Changed</b>	Filtered	Changed
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>36</b>	0	74
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m >15	<b>1</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>1</b>	<1	0
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	0	<1
Tin	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 50	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 15	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 15	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m 50	<b>2</b>	0	<1
Calcium	ppm	ASTM D5185m 50	<b>3</b>	2	0
Phosphorus	ppm	ASTM D5185m 350	<b>464</b>	575	510
Zinc	ppm	ASTM D5185m 100	<b>1</b>	0	0
Sulfur	ppm	ASTM D5185m 12500	<b>1125</b>	1233	1628

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>&lt;1</b>	0	3
Sodium	ppm	ASTM D5185m	<b>3</b>	<1	1
Potassium	ppm	ASTM D5185m >20	<b>4</b>	<1	<1
Water	%	ASTM D6304 >0.2	<b>▲ 0.630</b>	---	---
ppm Water	ppm	ASTM D6304 >2000	<b>▲ 6300</b>	---	---






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	<b>▲ 31528</b>	▲ 3082	---
Particles >6µm	ASTM D7647 >320	<b>▲ 17175</b>	▲ 709	---
Particles >14µm	ASTM D7647 >80	<b>▲ 2923</b>	60	---
Particles >21µm	ASTM D7647 >20	<b>▲ 985</b>	16	---
Particles >38µm	ASTM D7647 >4	<b>▲ 152</b>	1	---
Particles >71µm	ASTM D7647 >3	<b>▲ 16</b>	0	---
Oil Cleanliness	ISO 4406 (c) >17/15/13	<b>▲ 22/21/19</b>	▲ 19/17/13	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	<b>0.22</b>	0.39	0.35


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	MODER
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	▲ MODER
Debris	scalar	*Visual	NONE	<b>NONE</b>	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	<b>0.2%</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	320	<b>317</b>	316	312

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0120249  
**Lab Number** : 06131997  
**Unique Number** : 10951462  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**Received** : 28 Mar 2024  
**Tested** : 04 Apr 2024  
**Diagnosed** : 04 Apr 2024 - Jonathan Hester

**KraftHeinz - Springfield - Plant 8311 PCA**  
 2035 E BENNETT  
 SPRINGFIELD, MO  
 US 65804  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)