


# PROBLEM SUMMARY

Area  
**PROCESS CHEESE [98923824]**  
 Machine Id  
**COOKER 10**  
 Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (--- GAL)**



Sample Rating Trend



**WATER**



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

The oil change at the time of sampling has been noted. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition.

## PROBLEMATIC TEST RESULTS

Sample Status				<b>SEVERE</b>	SEVERE	ABNORMAL
Water	%	ASTM D6304	>0.2	▲ <b>0.737</b>	▲ 1.42	▲ 0.636
ppm Water	ppm	ASTM D6304	>2000	▲ <b>7370</b>	▲ 14200	▲ 6360
Particles >4µm		ASTM D7647	>1300	▲ <b>16564</b>	---	---
Particles >6µm		ASTM D7647	>320	▲ <b>9023</b>	---	---
Particles >14µm		ASTM D7647	>80	▲ <b>1536</b>	---	---
Particles >21µm		ASTM D7647	>20	▲ <b>517</b>	---	---
Particles >38µm		ASTM D7647	>4	▲ <b>80</b>	---	---
Particles >71µm		ASTM D7647	>3	▲ <b>8</b>	---	---
Oil Cleanliness		ISO 4406 (c)	>17/15/13	▲ <b>21/20/18</b>	---	---
Free Water	scalar	*Visual		▲ <b>2.0</b>	NEG	▲ 1.0

Customer Id: KRASPRMO  
 Sample No.: PCA0120252  
 Lab Number: 06131999  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.
Resample	---	---	?	We recommend an early resample to monitor this condition.

## HISTORICAL DIAGNOSIS

WATER



### 17 Jun 2023 Diag: Don Baldrige

We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. All component wear rates are normal. There is a high concentration of water present in the oil. There is a high amount of visible silt present in the sample. The AN level is acceptable for this fluid.

view report



WATER



### 17 Dec 2022 Diag: Doug Bogart

We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. There is too much water present in this sample to perform a particle count. Gear wear is indicated. There is a moderate concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.

view report



WATER



### 05 Nov 2022 Diag: Don Baldrige

We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. There is too much water present in this sample to perform a particle count. All component wear rates are normal. There is a moderate concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.


view report



# OIL ANALYSIS REPORT

Area  
Machine Id  
**PROCESS CHEESE [98923824]**  
Component  
**COOKER 10**  
Fluid  
**GEAR OIL ISO 320 (--- GAL)**

Sample Rating Trend



**WATER**



## DIAGNOSIS

### Recommendation

The oil change at the time of sampling has been noted. We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil. Free water present. There is a moderate concentration of water present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA0120252</b>	PCA0100128	PCA0076157
Sample Date	Client Info	<b>24 Mar 2024</b>	17 Jun 2023	17 Dec 2022
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>Changed</b>	Changed	Changed
Sample Status		<b>SEVERE</b>	SEVERE	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>136</b>	92	▲ 289
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	2
Nickel	ppm	ASTM D5185m >15	<b>2</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>1</b>	<1	<1
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	0	<1
Tin	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 50	<b>0</b>	21	0
Barium	ppm	ASTM D5185m 15	<b>0</b>	16	0
Molybdenum	ppm	ASTM D5185m 15	<b>0</b>	<1	<1
Manganese	ppm	ASTM D5185m	<b>1</b>	1	2
Magnesium	ppm	ASTM D5185m 50	<b>3</b>	16	1
Calcium	ppm	ASTM D5185m 50	<b>3</b>	26	5
Phosphorus	ppm	ASTM D5185m 350	<b>491</b>	316	546
Zinc	ppm	ASTM D5185m 100	<b>0</b>	123	0
Sulfur	ppm	ASTM D5185m 12500	<b>1767</b>	18017	1115

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>2</b>	3	4
Sodium	ppm	ASTM D5185m	<b>4</b>	29	15
Potassium	ppm	ASTM D5185m >20	<b>2</b>	4	<1
Water	%	ASTM D6304 >0.2	<b>▲ 0.737</b>	▲ 1.42	▲ 0.636
ppm Water	ppm	ASTM D6304 >2000	<b>▲ 7370</b>	▲ 14200	▲ 6360






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	<b>▲ 16564</b>	---	---
Particles >6µm	ASTM D7647 >320	<b>▲ 9023</b>	---	---
Particles >14µm	ASTM D7647 >80	<b>▲ 1536</b>	---	---
Particles >21µm	ASTM D7647 >20	<b>▲ 517</b>	---	---
Particles >38µm	ASTM D7647 >4	<b>▲ 80</b>	---	---
Particles >71µm	ASTM D7647 >3	<b>▲ 8</b>	---	---
Oil Cleanliness	ISO 4406 (c) >17/15/13	<b>▲ 21/20/18</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.85	<b>0.20</b>	1.20	0.36


# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	● MILKY	● MILKY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	▲ 0.2%	▲ 0.2%
Free Water	scalar	*Visual	▲ 2.0	NEG	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	331	223

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0120252  
**Lab Number** : 06131999  
**Unique Number** : 10951464  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**Received** : 28 Mar 2024  
**Tested** : 04 Apr 2024  
**Diagnosed** : 04 Apr 2024 - Jonathan Hester

**KraftHeinz - Springfield - Plant 8311 PCA**  
 2035 E BENNETT  
 SPRINGFIELD, MO  
 US 65804  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)