

OIL ANALYSIS REPORT


STUFF ROOM A [98899450]

KR-GR-003253 - EMULSIFIER VAC PUMP (S/N STUFF A - 11530626)

Component

Pump Fluid

R&O OIL ISO 100 (2 QTS)





DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. (Customer Sample Comment: 98899450)

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


	Αωχ ² 0222 Feb ² 023 Αωχ ² 023 Ματ ² 024						
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2	
Sample Number		Client Info		PCA0120377	PCA0102526	PCA0092409	
Sample Date		Client Info		20 Mar 2024	10 Aug 2023	11 Feb 2023	
Machine Age	hrs	Client Info		0	0	0	
Oil Age	hrs	Client Info		0	0	0	
Oil Changed		Client Info		N/A	N/A	N/A	
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL	
CONTAMINAT	ION	method	limit/base	current	history1	history2	
Water		WC Method	>.1	NEG	NEG	NEG	
WEAR METAL	S	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>90	6	3	<1	
Chromium	ppm	ASTM D5185m	>5	<1	0	<1	
Nickel	ppm	ASTM D5185m	>5	0	0	<1	
Titanium	ppm	ASTM D5185m	>3	<1	0	<1	
Silver	ppm	ASTM D5185m	>3	0	0	<1	
Aluminum	ppm	ASTM D5185m	>7	3	<1	0	
Lead	ppm	ASTM D5185m	>12	<1	0	3	
Copper	ppm	ASTM D5185m	>30	<1	0	<1	
Tin	ppm	ASTM D5185m	>9	<1	0	1	
Vanadium	ppm	ASTM D5185m		<1	0	<1	
Cadmium	ppm	ASTM D5185m		<1	0	<1	
ADDITIVES		method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	5	0	0	0	
Barium	ppm	ASTM D5185m	5	<1	0	0	
Molybdenum	ppm	ASTM D5185m	5	4	0	<1	
Manganese	ppm	ASTM D5185m		<1	0	0	
Magnesium	ppm	ASTM D5185m	5	2	0	11	
Calcium	ppm	ASTM D5185m	5	5	0	0	
Phosphorus	ppm	ASTM D5185m	100	569	4	5	
Zinc	ppm	ASTM D5185m	25	10	0	0	
Sulfur	ppm	ASTM D5185m	1500	1766	20	0	
CONTAMINAN	TS	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>60	<1	<1	1	
Sodium	ppm	ASTM D5185m		7	0	11	
Potassium	ppm	ASTM D5185m	>20	3	<1	27	
FLUID CLEANL	INESS	method	limit/base	current	history1	history2	
Particles >4µm		ASTM D7647	>10000	188634			
Particles >6µm		ASTM D7647	>2500	<u>^</u> 60771			
Particles >14µm		ASTM D7647	>640	<u> </u>			
Particles >21µm		ASTM D7647	>160	<u>^</u> 282			
Particles >38µm		ASTM D7647	>40	7			
Particles >71µm		ASTM D7647	>10	0			
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u>\$\text{\scale}\$ 25/23/18</u>			
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.08	0.16	0.085		



OIL ANALYSIS REPORT











Certificate L2367

Laboratory Sample No. Lab Number

: PCA0120377 : 06133212 Unique Number: 10952677

Received **Tested** Diagnosed

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 29 Mar 2024 : 01 Apr 2024

: 03 Apr 2024 - Jonathan Hester

KraftHeinz - Kirksville - Plant 8333 PCA

2504 INDUSTRIAL DR KIRKSVILLE, MO

US 63501

history2

history2

history2

Contact: WALLACE WARD wallace.ward@kraftheinzcompany.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Test Package: IND 2 (Additional Tests: PrtCount)

T: (660)627-1031 F: (660)627-5887