


# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

**GRIND ROOM [98763288]**

Machine Id

**KR-GR-002491 - INCLINE AUGER 8A (S/N GRIND A - 11513018)**

Component

**Gearbox**

Fluid

**PETRO CANADA 220 (17 QTS)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. ( Customer Sample Comment: 98763288 )

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA0116076</b>	PCA0110820	PCA0103746
Sample Date	Client Info	<b>11 Mar 2024</b>	06 Nov 2023	10 Aug 2023
Machine Age	hrs	<b>0</b>	0	0
Oil Age	hrs	<b>0</b>	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >200	<b>7</b>	16	16
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m >15	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>3</b>	0	<1
Lead	ppm	ASTM D5185m >100	<b>&lt;1</b>	<1	0
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m >25	<b>&lt;1</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	<1
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Calcium	ppm	ASTM D5185m	<b>4</b>	18	17
Phosphorus	ppm	ASTM D5185m	<b>447</b>	401	394
Zinc	ppm	ASTM D5185m	<b>3</b>	0	21
Sulfur	ppm	ASTM D5185m	<b>1509</b>	2556	2228

## CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	<b>3</b>	2	3
Sodium	ppm	ASTM D5185m	<b>0</b>	2	0
Potassium	ppm	ASTM D5185m >20	<b>1</b>	<1	<1
Water	%	ASTM D6304 >0.2	<b>0.034</b>	---	---
ppm Water	ppm	ASTM D6304 >2000	<b>340</b>	---	---

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>▲ 81930</b>	▲ 86437	▲ 112605
Particles >6µm	ASTM D7647 >2500	<b>▲ 8811</b>	▲ 14335	▲ 20564
Particles >14µm	ASTM D7647 >640	<b>367</b>	276	447
Particles >21µm	ASTM D7647 >160	<b>69</b>	54	69
Particles >38µm	ASTM D7647 >40	<b>0</b>	2	3
Particles >71µm	ASTM D7647 >10	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c) >20/18/16	<b>▲ 24/20/16</b>	▲ 24/21/15	▲ 24/22/16

## FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.50</b>	0.43	0.43

# OIL ANALYSIS REPORT


## Particle Trend




## Water (KF)




## Acid Number



## Water (KF)



## Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	224	259	252

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### Particle Count



### Acid Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : PCA0116076

**Lab Number** : 06133265

**Unique Number** : 10952730

**Test Package** : IND 2 ( Additional Tests: KF, PftCount )

**Received** : 29 Mar 2024

**Tested** : 05 Apr 2024

**Diagnosed** : 05 Apr 2024 - Jonathan Hester

**KraftHeinz - Kirksville - Plant 8333 PCA**

2504 INDUSTRIAL DR

KIRKSVILLE, MO

US 63501

Contact: WALLACE WARD

wallace.ward@kraftheinzcompany.com

T: (660)627-1031

F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)