


OIL ANALYSIS REPORT

Sample Rating Trend

DIRT


Area

LEGACY [98810770]

Machine Id

KR-HA-005546 - TRIMMER 1 SMALL (S/N HAM PACK - 10105268)

Component

Gear Reducer

Fluid

SCHAEFFER 294 SUPREME GEAR LUBE ISO 460 (--- GAL)
DIAGNOSIS
Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. (Customer Sample Comment: 98810770)

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal indicating ingress of seal material.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0116657	PCA0091770	PCA0093095
Sample Date	Client Info	14 Mar 2024	05 Sep 2023	26 Feb 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ATTENTION	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.1	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >150	23	1	2
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >10	<1	0	0
Titanium	ppm	ASTM D5185m	3	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	3	<1	0
Lead	ppm	ASTM D5185m >100	<1	2	0
Copper	ppm	ASTM D5185m >50	86	2	34
Tin	ppm	ASTM D5185m >10	7	0	2
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 124	0	7	3
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m 306	8	33	99
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 0	3	2	0
Calcium	ppm	ASTM D5185m 23	212	18	24
Phosphorus	ppm	ASTM D5185m 1100	555	526	543
Zinc	ppm	ASTM D5185m 2	5	0	0
Sulfur	ppm	ASTM D5185m 25200	953	3639	5164

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >50	64	4	7
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	1	0	<1

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	397470	---	---
Particles >6µm	ASTM D7647 >2500	231295	---	---
Particles >14µm	ASTM D7647 >640	10526	---	---
Particles >21µm	ASTM D7647 >160	1304	---	---
Particles >38µm	ASTM D7647 >40	26	---	---
Particles >71µm	ASTM D7647 >10	2	---	---
Oil Cleanliness	ISO 4406 (c) >20/18/16	26/25/21	---	---

FLUID DEGRADATION


method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.54	---	---

OIL ANALYSIS REPORT


▲ Particle Trend




▲ Silicon (ppm)




▲ Non-ferrous Metals



▲ Silicon (ppm)



Acid Number



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	MODER	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	MODER
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	MODER	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	467.5	440	230.1 432

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color




Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PCA0116657

Lab Number : 06133272

Unique Number : 10952737

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 29 Mar 2024

Tested : 01 Apr 2024

Diagnosed : 03 Apr 2024 - Jonathan Hester

KraftHeinz - Kirksville - Plant 8333 PCA

2504 INDUSTRIAL DR

KIRKSVILLE, MO

US 63501

Contact: WALLACE WARD

wallace.ward@kraftheinzcompany.com

T: (660)627-1031

F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)