

OIL ANALYSIS REPORT

Area **7203** Machine Id 723-UCLR-GBX

Component **Gearbox**

GEAR OIL ISO 220 (--- GAL)

Sample Rating Trend NORMAL

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0071550		
Sample Date		Client Info		17 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	46		
Chromium	ppm	ASTM D5185m	>15	0		
Nickel	ppm	ASTM D5185m	>15	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>100	0		
Copper	ppm	ASTM D5185m	>200	0		
Tin	ppm	ASTM D5185m	>25	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	3		
Barium	ppm	ASTM D5185m	15	5		
Molybdenum	ppm	ASTM D5185m	15	0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m	50	0		
Calcium	ppm	ASTM D5185m	50	32		
Phosphorus	ppm	ASTM D5185m	350	440		
Zinc	ppm	ASTM D5185m	100	25		
Sulfur	ppm	ASTM D5185m	12500	18364		
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	9		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	1.01		



OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.2	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPE	RTIFS	method	limit/base	current	historv1	historv2


TEOID THOTELTHE				
Visc @ 40°C cSt	ASTM D445	220	188	


SAMPLE IMAGES	method	limit/base	current	history1	history2
Color		٥		no image	no image
Bottom				no image	no image
CDADUC					

GRAPHS



10-	Non-ferrous Metals
8-	copper
mdd .	sessessesses (II)
2.	
0	
	Mar17/24
	Viscosity @ 40°C









Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: PCA0071550 Lab Number : 06137559

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Unique Number : 10957024

Received **Tested** Diagnosed

: 03 Apr 2024 : 04 Apr 2024 : 05 Apr 2024 - Don Baldridge

100 WORTHINGTON DR PORTER, IN US 46304

WORTHINGTON INDUSTRIES

Contact: ROBERT HARDIN robert.hardin@worthingtonindustries.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: WORPOR [WUSCAR] 06137559 (Generated: 04/06/2024 02:03:34) Rev: 1

Submitted By: ADAM POTTS

T:

F: