


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

L-7 62 REDUCTION

Component Gearbox

PETRO CANADA ENDURATEX EP 150 (20 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		SCEOTT MUGEO	TO May2013 Ma2020 N	UVZUZU GODZUZI WIBYZUZZ GBIIZUZ	3 002023	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0116750	PCA0091816	PCA0091832
Sample Date		Client Info		08 Apr 2024	18 Oct 2023	14 Jul 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ABNORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184		47	31	32
Iron	ppm	ASTM D5185m	>200	91	94	152
Chromium	ppm	ASTM D5185m	>15	<1	<1	<1
Nickel	ppm	ASTM D5185m	>15	0	<1	0
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	0
Lead	ppm	ASTM D5185m	>100	0	<1	<1
Copper	ppm	ASTM D5185m	>200	0	<1	<1
Tin	ppm	ASTM D5185m	>25	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	55	40	46	39
Barium	ppm	ASTM D5185m	0	0	<1	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	<1
Manganese	ppm	ASTM D5185m	0	1	1	<1
Magnesium	ppm	ASTM D5185m	2	0	<1	0
Calcium	ppm	ASTM D5185m	6	0	<1	0
Phosphorus	ppm	ASTM D5185m	250	417	436	543
Zinc	ppm	ASTM D5185m	3	0	0	4
Sulfur	ppm	ASTM D5185m	7500	6593	6933	6751
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1	2	<1
Sodium	ppm	ASTM D5185m		1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	2	2
FLUID DEGRA	DATION	method	limit/base	current	history1	history2

1.30

Acid Number (AN)


mg KOH/g ASTM D8045 0.5

1.23


1.15



OIL ANALYSIS REPORT



Vis	cosity	@ 40	0°C					
le e	ormal							
160								
ු 155 -					-144			
0-155 0-150 Base 145					Λ			
	/	-	$\overline{}$			$\overline{}$		
140								
135 - Abn	ormal							
-	8/18	3/19	1/20	1/20	2/21	1/22	5/23	3/23
Dec17/1	Aug16/18	May28/19	Mari	Nov4/	Sep2/	May7/2	Jan5/	Oct18/23
	4		_					



VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	MODER	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIES	method	limit/hase	current	history1	history2


I LOID I HOI						
Visc @ 40°C	cSt	ASTM D445	150.0	146	146	147

SAN	1PLE	IMA	GES	

Color

Bottom









Certificate 12367

Laboratory Sample No.

Lab Number : 06142425 Unique Number : 10967233

: PCA0116750

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 08 Apr 2024 **Tested** : 09 Apr 2024

Diagnosed : 09 Apr 2024 - Wes Davis

Test Package : PLANT To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

bruce.a.james@saint-gobain.com T: (828)459-3320 F: (828)459-3329

Contact: BRUCE JAMES

CERTAINTEED VINYL PLANT

2651 PENNY RD

CLAREMONT, NC

US 28613