


OIL ANALYSIS REPORT



LITTLE KICE

Component South Blower Fluid HYDROTEX Ultra-Kleen ISO 220 (1 GAL)

DIAGNOSIS

Machine Id

A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0123872	PCA0110387	
Sample Date		Client Info		04 Apr 2024	08 Jan 2024	
Machine Age	yrs	Client Info		0	1	
Oil Age	yrs	Client Info		0	1	
Oil Changed		Client Info		Not Changd	Not Changd	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METAL	S	method	limit/base	current	history1	history2
PQ		ASTM D8184		24	34	
Iron	ppm	ASTM D5185m	>20	13	17	
Chromium	ppm	ASTM D5185m	>20	<1	0	
Nickel	ppm	ASTM D5185m	>20	<1	<1	
Titanium	ppm	ASTM D5185m		<1	<1	
Silver	ppm	ASTM D5185m		<1	0	
Aluminum	ppm	ASTM D5185m	>20	1	<1	
Lead	ppm	ASTM D5185m	>20	1	<1	
Copper	ppm	ASTM D5185m	>20	4	3	
Tin	ppm	ASTM D5185m	>20	1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	3	
Barium	ppm	ASTM D5185m		<1	0	
Molybdenum	ppm	ASTM D5185m		<1	0	
Manganese	ppm	ASTM D5185m		1	<1	
Magnesium	ppm	ASTM D5185m		31	39	
Calcium	ppm	ASTM D5185m		28	29	
Phosphorus	ppm	ASTM D5185m		277	276	
Zinc	ppm	ASTM D5185m		209	237	
Sulfur	ppm	ASTM D5185m		3903	3803	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<u> </u>	5 9	
Sodium	ppm	ASTM D5185m		1	3	
Potassium	ppm	ASTM D5185m	>20	2	2	
Water	%	ASTM D6304		NEG	NEG	
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.34	0.32	



OIL ANALYSIS REPORT







Report Id: ARDNEWKS [WUSCAR] 06146003 (Generated: 04/15/2024 19:19:18) Rev: 1

Certificate 12367

Laboratory

Sample No.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: STEVEN GRABENDIKE - ARDNEWKS

F: