


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
Smith Ridge 1

Component
Natural Gas Engine

Fluid
CITGO PACEMAKER GAS ENGIN 1700 SERIES 40W (--- GAL)

DIAGNOSIS

Recommendation
We recommend that you drain the oil and perform a filter service on this component if not already done. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear
Bearing and/or bushing wear is indicated.

Contamination
Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition
The BN level is low. The AN level is at the top-end of the recommended limit. The oil is no longer serviceable as a result of the abnormal and/or severe wear.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0117146	PCA0117144	PCA0117139
Sample Date	Client Info		01 Apr 2024	05 Mar 2024	06 Feb 2024
Machine Age	hrs	Client Info	185876	185258	184598
Oil Age	hrs	Client Info	185876	185258	184598
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			SEVERE	ABNORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	10	5	5
Chromium	ppm	ASTM D5185m >4	1	<1	<1
Nickel	ppm	ASTM D5185m >2	<1	<1	<1
Titanium	ppm	ASTM D5185m	2	1	1
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	2	2	2
Lead	ppm	ASTM D5185m >30	▲ 94	▲ 39	5
Copper	ppm	ASTM D5185m >35	16	11	12
Tin	ppm	ASTM D5185m >4	2	1	<1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	<1	0	0
Molybdenum	ppm	ASTM D5185m	3	1	<1
Manganese	ppm	ASTM D5185m	1	<1	<1
Magnesium	ppm	ASTM D5185m	19	22	21
Calcium	ppm	ASTM D5185m	1620	1517	1404
Phosphorus	ppm	ASTM D5185m	351	318	314
Zinc	ppm	ASTM D5185m	430	419	382
Sulfur	ppm	ASTM D5185m	2916	2489	2469

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	3	2	2
Sodium	ppm	ASTM D5185m	8	10	10
Potassium	ppm	ASTM D5185m >20	3	2	2
Fuel	%	ASTM D3524 >4.0	0.3	0.3	0.3

INFRA-RED


	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0	0
Nitration	Abs/cm	*ASTM D7624 >20	8.6	7.0	5.5
Sulfation	Abs/.1mm	*ASTM D7415 >30	22.5	20.3	18.0

FLUID DEGRADATION


	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	22.8	18.7	14.2
Acid Number (AN)	mg KOH/g	ASTM D8045	▲ 2.60	1.90	1.17
Base Number (BN)	mg KOH/g	ASTM D2896	▲ 2.36	3.12	3.05

OIL ANALYSIS REPORT


▲ Non-ferrous Metals




▲ Acid Number




● Fuel Dilution



FT-IR (Direct Trend)



FT-IR (Direct Trend)




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.8	14.2	13.8

GRAPHS


Iron (ppm)




Aluminum (ppm)




Copper (ppm)




Viscosity @ 100°C




▲ Lead (ppm)




Chromium (ppm)



Silicon (ppm)



▲ Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0117146 **Received** : 11 Apr 2024
Lab Number : 06146067 **Tested** : 16 Apr 2024
Unique Number : 10976145 **Diagnosed** : 16 Apr 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

ENERVEST OPERATING - SMITH RIDGE
 2305 SMITH RIDGE
 MCCLURE, VA
 US 24269
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: