




# PROBLEM SUMMARY

Area  
**PASTA [98778116]**  
 Machine Id  
**A PRESS VACUUM MIXER**  
 Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (--- GAL)**



Sample Rating Trend



WATER



## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you check all areas where dirt can enter the system. We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

## PROBLEMATIC TEST RESULTS

| Sample Status    |        |             |       | SEVERE  | ABNORMAL | ABNORMAL |
|------------------|--------|-------------|-------|---------|----------|----------|
| Silicon          | ppm    | ASTM D5185m | >50   | ▲ 109   | 43       | 15       |
| Water            | %      | ASTM D6304  | >0.2  | ▲ 0.217 | 0.047    | 0.070    |
| ppm Water        | ppm    | ASTM D6304  | >2000 | ▲ 2170  | 470      | 700      |
| Emulsified Water | scalar | *Visual     | >0.2  | ▲ 0.2%  | 0.2%     | 0.2%     |
| Free Water       | scalar | *Visual     |       | ▲ 5.0   | NEG      | NEG      |

Customer Id: KRASPRMO  
 Sample No.: PCA0120273  
 Lab Number: 06150263  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

| Action             | Status | Date | Done By | Description   |
|--------------------|--------|------|---------|---|
| Resample           | ---    | ---  | ?       | We recommend an early resample to monitor this condition.           |
| Check Dirt Access  | ---    | ---  | ?       | We advise that you check all areas where dirt can enter the system. |
| Check Water Access | ---    | ---  | ?       | We advise that you check for the source of water entry.             |

## HISTORICAL DIAGNOSIS

### CONTAMINANT



#### 30 Sep 2023 Diag: Don Baldrige

The oil change at the time of sampling has been noted. We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Appearance is hazy. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

[view report](#)



### ISO



#### 28 Aug 2023 Diag: Doug Bogart

The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### VIS DEBRIS



#### 26 May 2023 Diag: Don Baldrige


The oil change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid.

[view report](#)



# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area  
**PASTA [98778116]**  
 Machine Id  
**A PRESS VACUUM MIXER**  
 Component  
**Gearbox**  
 Fluid  
**GEAR OIL ISO 320 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you check all areas where dirt can enter the system. We advise that you check for the source of water entry. The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count.

### Wear

All component wear rates are normal.

### ▲ Contamination

Elemental level of silicon (Si) above normal. There is a light concentration of water present in the oil. Excessive free water present.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

## SAMPLE INFORMATION

| method        | limit/base  | current            | history1    | history2    |
|---------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | <b>PCA0120273</b>  | PCA0099589  | PCA0099585  |
| Sample Date   | Client Info | <b>24 Mar 2024</b> | 30 Sep 2023 | 28 Aug 2023 |
| Machine Age   | hrs         | <b>0</b>           | 0           | 0           |
| Oil Age       | hrs         | <b>0</b>           | 0           | 0           |
| Oil Changed   | Client Info | <b>Changed</b>     | Changed     | Changed     |
| Sample Status |             | <b>SEVERE</b>      | ABNORMAL    | ABNORMAL    |

## WEAR METALS

| method   | limit/base           | current      | history1 | history2 |
|----------|----------------------|--------------|----------|----------|
| Iron     | ppm ASTM D5185m >200 | <b>61</b>    | 40       | 0        |
| Chromium | ppm ASTM D5185m >15  | <b>&lt;1</b> | 0        | 0        |
| Nickel   | ppm ASTM D5185m >15  | <b>0</b>     | 0        | 0        |
| Titanium | ppm ASTM D5185m      | <b>&lt;1</b> | 0        | 0        |
| Silver   | ppm ASTM D5185m      | <b>0</b>     | 0        | 0        |
| Aluminum | ppm ASTM D5185m >25  | <b>0</b>     | 0        | 1        |
| Lead     | ppm ASTM D5185m >100 | <b>0</b>     | 0        | 0        |
| Copper   | ppm ASTM D5185m >200 | <b>&lt;1</b> | 0        | 0        |
| Tin      | ppm ASTM D5185m >25  | <b>&lt;1</b> | 0        | 0        |
| Vanadium | ppm ASTM D5185m      | <b>0</b>     | 0        | 0        |
| Cadmium  | ppm ASTM D5185m      | <b>0</b>     | 0        | 0        |

## ADDITIVES

| method     | limit/base            | current      | history1 | history2 |
|------------|-----------------------|--------------|----------|----------|
| Boron      | ppm ASTM D5185m 50    | <b>0</b>     | 0        | 0        |
| Barium     | ppm ASTM D5185m 15    | <b>0</b>     | 0        | 0        |
| Molybdenum | ppm ASTM D5185m 15    | <b>0</b>     | 0        | 0        |
| Manganese  | ppm ASTM D5185m       | <b>&lt;1</b> | 0        | 0        |
| Magnesium  | ppm ASTM D5185m 50    | <b>&lt;1</b> | <1       | 2        |
| Calcium    | ppm ASTM D5185m 50    | <b>0</b>     | 0        | 0        |
| Phosphorus | ppm ASTM D5185m 350   | <b>483</b>   | 531      | 508      |
| Zinc       | ppm ASTM D5185m 100   | <b>0</b>     | 0        | 0        |
| Sulfur     | ppm ASTM D5185m 12500 | <b>1521</b>  | 1391     | 1642     |

## CONTAMINANTS

| method    | limit/base           | current        | history1 | history2 |
|-----------|----------------------|----------------|----------|----------|
| Silicon   | ppm ASTM D5185m >50  | <b>▲ 109</b>   | 43       | 15       |
| Sodium    | ppm ASTM D5185m      | <b>12</b>      | 11       | <1       |
| Potassium | ppm ASTM D5185m >20  | <b>1</b>       | 4        | 4        |
| Water     | % ASTM D6304 >0.2    | <b>▲ 0.217</b> | 0.047    | 0.070    |
| ppm Water | ppm ASTM D6304 >2000 | <b>▲ 2170</b>  | 470      | 700      |





## FLUID CLEANLINESS

| method          | limit/base             | current | history1 | history2   |
|-----------------|------------------------|---------|----------|------------|
| Particles >4µm  | ASTM D7647 >1300       | ---     | ---      | ● 1714     |
| Particles >6µm  | ASTM D7647 >320        | ---     | ---      | ▲ 934      |
| Particles >14µm | ASTM D7647 >80         | ---     | ---      | ● 159      |
| Particles >21µm | ASTM D7647 >20         | ---     | ---      | ▲ 54       |
| Particles >38µm | ASTM D7647 >4          | ---     | ---      | ● 8        |
| Particles >71µm | ASTM D7647 >3          | ---     | ---      | 1          |
| Oil Cleanliness | ISO 4406 (c) >17/15/13 | ---     | ---      | ▲ 18/17/14 |

## FLUID DEGRADATION

| method           | limit/base               | current     | history1 | history2 |
|------------------|--------------------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g ASTM D8045 0.85 | <b>0.49</b> | 0.28     | 0.38     |


# OIL ANALYSIS REPORT







| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | NONE     | NONE     |
| Debris           | scalar | *Visual    | NONE    | NONE     | ▲ MODER  |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | ● HAZY   | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >0.2    | ▲ 0.2%   | 0.2%     |
| Free Water       | scalar | *Visual    |         | ▲ 5.0    | NEG      |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C      | cSt    | ASTM D445  | 320     | 329      | 332      |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0120273  
**Lab Number** : 06150263  
**Unique Number** : 10980341  
**Test Package** : IND 2 ( Additional Tests: KF, PftCount )

**KraftHeinz - Springfield - Plant 8311 PCA**  
 2035 E BENNETT  
 SPRINGFIELD, MO  
 US 65804  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: