


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

LINE 6 [908197396]

Machine Id

[LINE 6] L6 YT-43012 L6 YT-43012

Component

Gearbox

Fluid

PETRO CANADA PURITY FG EP GEAR FLUID 460 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.
NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0111058	PCA0100817	PCA0078620
Sample Date	Client Info	23 Mar 2024	01 Aug 2023	12 Jan 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		NORMAL	NORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	29	17	7
Iron	ppm ASTM D5185m >200	13	6	5
Chromium	ppm ASTM D5185m >15	<1	0	0
Nickel	ppm ASTM D5185m >15	0	0	0
Titanium	ppm ASTM D5185m	<1	<1	0
Silver	ppm ASTM D5185m	<1	0	0
Aluminum	ppm ASTM D5185m >25	6	8	2
Lead	ppm ASTM D5185m >100	<1	0	<1
Copper	ppm ASTM D5185m >200	<1	2	1
Tin	ppm ASTM D5185m >25	<1	0	<1
Antimony	ppm ASTM D5185m >5	---	---	---
Vanadium	ppm ASTM D5185m	<1	<1	0
Cadmium	ppm ASTM D5185m	<1	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	0	1	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	0	0	<1
Magnesium	ppm ASTM D5185m	<1	3	1
Calcium	ppm ASTM D5185m	10	61	3
Phosphorus	ppm ASTM D5185m 135	626	554	538
Zinc	ppm ASTM D5185m	7	38	10
Sulfur	ppm ASTM D5185m 660	505	639	399




CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	7	5	6
Sodium	ppm ASTM D5185m	4	2	0
Potassium	ppm ASTM D5185m >20	2	2	<1

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.54	0.90	0.87	0.80


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	460	419	413	414

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0111058 **Received** : 19 Apr 2024
Lab Number : **06154583** **Tested** : 22 Apr 2024
Unique Number : 10990006 **Diagnosed** : 22 Apr 2024 - Wes Davis
Test Package : IND 2 (Additional Tests: PQ)

THE HERSHEY COMPANY
 WEST HERSHEY - TECHNICAL ASSURANCE, 1033 OLDE WEST CHOCOLATE
 HERSHEY, PA
 US 17033
 Contact: CLINTON ZOHNER
 clintzohner@hersheys.com
 T: (717)374-4846
 F: (717)374-4594

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)