

COOLANT REPORT

Sample Rating Trend



NORMAL



Machine Id
ASL237796
Component
Coolant
Fluid
{not provided} (--- GAL)

DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.



SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0104445	---	---
Sample Date	Client Info		13 Apr 2024	---	---
Machine Age	hrs	Client Info	581	---	---
Oil Age	hrs	Client Info	3132	---	---
Oil Changed		Client Info	N/A	---	---
Sample Status			NORMAL	---	---


PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Glycol Type	FT-IR		---	---	---
Specific Gravity	*ASTM D1298		1.066	---	---
pH	Scale 0-14 ASTM D1287		8.32	---	---
Nitrites	ppm AP-053:2009		748	---	---
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321		48.8	---	---
Freezing Point	°F ASTM D3321		-31	---	---
Total Dissolved Solids			303.5	---	---
Carboxylate			n/a	---	---







VISUAL

	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	---	---
Coolant Appearance	*Visual	Clear	normal	---	---
Color				no image	no image
Bottom				no image	no image

COOLANT REPORT



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0104445 **Received** : 19 Apr 2024
Lab Number : 06155029 **Tested** : 22 Apr 2024
Unique Number : 10990452 **Diagnosed** : 24 Apr 2024 - Jonathan Hester
Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType)

UMM - Shop 401 - Norton
 186 South Washington Street
 Norton, MA
 US 02766
 Contact: P Cohen
 pcohen@win-waste.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)