


PROBLEM SUMMARY

Sample Rating Trend



Area

MIX ROOM D [98937084]


KR-GR-000325-NORTH - 15000 LB MIXER (S/N MIX D - 11513074)


Gear Reducer

Fluid

PETRO CANADA 220 (48 LTR)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. (Customer Sample Comment: 98937084)

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	SEVERE	SEVERE		
Water	%	ASTM D6304	>0.1	▲ 5.33	△ 0.472	▲ 1.17		
ppm Water	ppm	ASTM D6304	>1000	53300	▲ 4723	1 1700		
Emulsified Water	scalar	*Visual	>0.1	0.2%	△ 0.2%	▲ 0.2%		
Free Water	scalar	*Visual		▲ >10%	▲ >10%	NEG		
Visc @ 40°C	cSt	ASTM D445		4 249	234	227		

Customer Id: KRAKIR Sample No.: PCA0114144 Lab Number: 06155878 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.		
Resample			?	We recommend an early resample to monitor this condition.		
Check Water Access			?	We advise that you check for the source of water entry.		

HISTORICAL DIAGNOSIS

22 Jan 2024 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. All component wear rates are normal. Excessive free water present. There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



20 Oct 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We recommend an early resample to monitor this condition.All component wear rates are normal. Appearance is milky. There is a high concentration of water present in the oil. The AN level is acceptable for this fluid.



16 Aug 2023 Diag: Jonathan Hester






We advise that you check for the source of water entry. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a moderate concentration of water present in the oil. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend



Area

MIX ROOM D [98937084]

KR-GR-000325-NORTH - 15000 LB MIXER (S/N MIX D - 11513074)

Gear Reducer

Fluid

PETRO CANADA 220 (48 LTR)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. There is too much water present in this sample to perform a particle count. (Customer Sample Comment: 98937084)

Wear

All component wear rates are normal.

Contamination

There is a high concentration of water present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info	IIIIIIV Dase	PCA0114144	PCA0108441	PCA0108232
Sample Date		Client Info		17 Apr 2024	22 Jan 2024	20 Oct 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1113	Client Info		Not Changd	N/A	N/A
Sample Status		Ciletit IIIIO		SEVERE	SEVERE	SEVERE
	C	us a tla a al	limit/lenene			
WEAR METAL	.5	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>150	144	75	62
Chromium	ppm	ASTM D5185m	>10	2	0	<1
Nickel	ppm	ASTM D5185m	>10	0	0	2
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	<1	0	1
Lead	ppm	ASTM D5185m	>100	<1	0	1
Copper	ppm	ASTM D5185m	>50	<1	0	0
Tin	ppm	ASTM D5185m	>10	2	<1	2
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		2	0	<1
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		18	1	8
Manganese	ppm	ASTM D5185m		1	<1	1
Magnesium	ppm	ASTM D5185m		1	0	5
Calcium	ppm	ASTM D5185m		13	6	13
Phosphorus	ppm	ASTM D5185m		345	344	426
Zinc	ppm	ASTM D5185m		11	11	2
Sulfur	ppm	ASTM D5185m		3611	1095	2011
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	3	2	4
Sodium	ppm	ASTM D5185m		3	4	4
Potassium	ppm	ASTM D5185m	>20	3	2	5
Water	%	ASTM D6304	>0.1	▲ 5.33	△ 0.472	1.17
ppm Water	ppm	ASTM D6304	>1000	▲ 53300	▲ 4723	▲ 11700
FLUID CLEAN	LINESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000		400	
Particles >6µm		ASTM D7647	>2500		218	
Particles >14μm		ASTM D7647	>640		37	
Particles >21µm		ASTM D7647	>160		12	
Particles >38µm		ASTM D7647	>40		2	
Particles >71µm		ASTM D7647	>10		0	
Oil Cleanliness		ISO 4406 (c)	>20/18/16		16/15/12	
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
A 1151 1 (A10)	1/01::	A OTHER DOC :-			0.04=	

Acid Number (AN)

mg KOH/g ASTM D8045


0.617


0.26


0.30




OIL ANALYSIS REPORT









FLUID PROPE	RHES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	_	249	234	227


SAMPLE IMAGES


Color


Bottom




GRAPHS













Laboratory Sample No. Lab Number : 06155878

: PCA0114144

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** Unique Number : 10991301

: 22 Apr 2024 Diagnosed

: 24 Apr 2024 : 24 Apr 2024 - Don Baldridge

KraftHeinz - Kirksville - Plant 8333 PCA 2504 INDUSTRIAL DR KIRKSVILLE, MO

US 63501 Contact: WALLACE WARD

F: (660)627-5887

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

wallace.ward@kraftheinzcompany.com T: (660)627-1031

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: KRAKIR [WUSCAR] 06155878 (Generated: 04/24/2024 17:50:16) Rev: 1

Submitted By: Wilberto Pacheco Garcia