




# OIL ANALYSIS REPORT



Area  
**(C0810283) {UNASSIGNED}**  
 Machine Id  
**834016**  
 Component  
**Natural Gas Engine**  
 Fluid  
**PETRO CANADA DURON SHP 15W40 (8 GAL)**

Sample Rating Trend



**NORMAL**

## DIAGNOSIS

**Recommendation**  
 Resample at the next service interval to monitor.

**Wear**  
 All component wear rates are normal.

**Contamination**  
 There is no indication of any contamination in the oil.

**Fluid Condition**  
 The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>GFL0118026</b>	GFL0109914	GFL0109870
Sample Date	Client Info		<b>23 Apr 2024</b>	29 Jan 2024	12 Jan 2024
Machine Age	hrs	Client Info	<b>1212</b>	1194	1098
Oil Age	hrs	Client Info	<b>27</b>	594	507
Oil Changed	Client Info		<b>Not Changed</b>	Changed	Not Changed
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>25</b>	23	28
Chromium	ppm	ASTM D5185m >4	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m >2	<b>0</b>	<1	<1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >9	<b>0</b>	2	2
Lead	ppm	ASTM D5185m >30	<b>0</b>	4	3
Copper	ppm	ASTM D5185m >35	<b>&lt;1</b>	4	5
Tin	ppm	ASTM D5185m >4	<b>0</b>	2	1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>12</b>	0	0
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	3
Molybdenum	ppm	ASTM D5185m 60	<b>66</b>	61	66
Manganese	ppm	ASTM D5185m 0	<b>&lt;1</b>	2	2
Magnesium	ppm	ASTM D5185m 1010	<b>991</b>	865	956
Calcium	ppm	ASTM D5185m 1070	<b>1226</b>	1042	1139
Phosphorus	ppm	ASTM D5185m 1150	<b>1121</b>	848	882
Zinc	ppm	ASTM D5185m 1270	<b>1394</b>	1111	1174
Sulfur	ppm	ASTM D5185m 2060	<b>3822</b>	2479	3017

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	<b>3</b>	9	9
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	6	4
Potassium	ppm	ASTM D5185m >20	<b>&lt;1</b>	3	4

## INFRA-RED




	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624 >20	<b>5.5</b>	10.0	9.9
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>17.9</b>	21.7	20.3

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>12.8</b>	16.1	15.4
Base Number (BN)	mg KOH/g	ASTM D2896 9.8	<b>7.7</b>	2.9	3.4







# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.4	13.7	13.1

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : GFL0118026      **Received** : 24 Apr 2024  
**Lab Number** : 06158743      **Tested** : 25 Apr 2024  
**Unique Number** : 10994166      **Diagnosed** : 25 Apr 2024 - Wes Davis  
**Test Package** : FLEET

**GFL Environmental - 010 - Stockbridge**  
 1280 Rum Creek Parkway  
 Stockbridge, GA  
 US 30281  
 Contact: JOSHUA TINKER  
 joshuatinker@gflenv.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)