

OIL ANALYSIS REPORT



Machine Id 391365 Component Diesel Engine

Fluid PETRO CANADA DURON SHP 10W30 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the component make and model with your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

(13)				Aprzuz4		
SAMPLE INFOR	RMATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0101995		
Sample Date		Client Info		25 Apr 2024		
Machine Age	mls	Client Info		110820		
Oil Age	mls	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINAT	FION	method	limit/base	current	history1	history2
Fuel		WC Method	>5	<1.0		
Water		WC Method	>0.2	NEG		
Glycol		WC Method		NEG		
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	6		
Chromium	ppm	ASTM D5185m	>20	<1		
Nickel	ppm	ASTM D5185m	>4	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m	>3	<1		
Aluminum	ppm	ASTM D5185m	>20	2		
Lead	ppm	ASTM D5185m	>40	<1		
Copper	ppm	ASTM D5185m	>330	<1		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	23		
Barium	ppm	ASTM D5185m	0	2		
Molybdenum	ppm	ASTM D5185m	50	66		
Manganese	ppm	ASTM D5185m	0	<1		
Magnesium	ppm	ASTM D5185m	950	1015		
Calcium	ppm	ASTM D5185m	1050	1222		
Phosphorus	ppm	ASTM D5185m	995	1150		
Zinc	ppm	ASTM D5185m	1180	1359		
Sulfur	ppm	ASTM D5185m	2600	3848		
CONTAMINAN	NTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	2		
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	0.3		
Nitration	Abs/cm	*ASTM D7624	>20	6.3		
Sulfation	Abs/.1mm	*ASTM D7415	>30	17.4		
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	13.7		
Base Number (BN)	mg KOH/g	ASTM D2896		8.7		





OIL ANALYSIS REPORT





8 Apr25/24





To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: MILPEN [WUSCAR] 06161238 (Generated: 04/27/2024 04:27:03) Rev: 1

Certificate 12367

Laboratory

Sample No.

Contact/Location: MIKE BOYER - MILPEN

mboyer@millertransgroup.com

T: (856)662-4264

F: (856)663-4898