


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
Hurricane Creek 3

Component
Natural Gas Engine

Fluid
PETRO CANADA SENTRON LD 3000 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		PCA0111998	PCA0112001	PCA0112006
Sample Date	Client Info		02 May 2024	02 Apr 2024	04 Mar 2024
Machine Age	hrs	Client Info	145274	144559	143866
Oil Age	hrs	Client Info	5889	5174	4481
Oil Changed	Client Info		Not Changed	Not Changed	Not Changed
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	1	1	0
Chromium	ppm	ASTM D5185m >4	<1	<1	0
Nickel	ppm	ASTM D5185m >2	<1	<1	0
Titanium	ppm	ASTM D5185m	<1	<1	0
Silver	ppm	ASTM D5185m >3	0	0	0
Aluminum	ppm	ASTM D5185m >9	<1	1	1
Lead	ppm	ASTM D5185m >30	1	1	<1
Copper	ppm	ASTM D5185m >35	<1	<1	0
Tin	ppm	ASTM D5185m >4	1	1	<1
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	<1	<1	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	0	0	0
Barium	ppm	ASTM D5185m 1	0	0	0
Molybdenum	ppm	ASTM D5185m 2	2	2	0
Manganese	ppm	ASTM D5185m 1	<1	<1	<1
Magnesium	ppm	ASTM D5185m 5	8	7	9
Calcium	ppm	ASTM D5185m 1220	1289	1280	1206
Phosphorus	ppm	ASTM D5185m 298	286	303	272
Zinc	ppm	ASTM D5185m 350	344	343	343
Sulfur	ppm	ASTM D5185m 1995	2588	2651	2242

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >+100	2	2	1
Sodium	ppm	ASTM D5185m >20	0	0	1
Potassium	ppm	ASTM D5185m >20	3	2	1
Fuel	%	ASTM D3524 >4.0	0.0	0.1	0.1






INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0	0	0
Nitration	Abs/cm	*ASTM D7624 >15	3.6	3.5	3.4
Sulfation	Abs/.1mm	*ASTM D7415 >25	13.8	14.0	13.9

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >20	7.8	7.9	7.6
Acid Number (AN)	mg KOH/g	ASTM D8045 0.86	0.789	0.633	0.23
Base Number (BN)	mg KOH/g	ASTM D2896 3.9	3.83	3.76	3.84









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.7	13.1	13.1

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PCA0111998

Lab Number : 06174049

Unique Number : 11020102

Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

Received : 09 May 2024

Tested : 15 May 2024

Diagnosed : 15 May 2024 - Don Baldrige

ENERVEST OPERATING - HURRICANE

2830 LAUREL BRANCH ROAD

VANSANT, VA

US 24656

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: