


OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id

9
Component
Natural Gas Engine
Fluid
PETRO CANADA SENTRON LD 3000 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The copper level is abnormal. All other component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0112040	PCA0117153	PCA0117184
Sample Date	Client Info	02 May 2024	02 Apr 2024	04 Mar 2024
Machine Age	hrs	Client Info	138712	138052
Oil Age	hrs	Client Info	306	5305
Oil Changed	Client Info	Not Chngd	Not Chngd	Not Chngd
Sample Status		ABNORMAL	NORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2	
Water	WC Method	>0.1	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2		
Iron	ppm	ASTM D5185m	>50	4	3	<1
Chromium	ppm	ASTM D5185m	>4	<1	<1	0
Nickel	ppm	ASTM D5185m	>2	<1	<1	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	<1	1	1
Lead	ppm	ASTM D5185m	>30	1	2	0
Copper	ppm	ASTM D5185m	>35	36	12	0
Tin	ppm	ASTM D5185m	>4	1	1	<1
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	<1	0

ADDITIVES

method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	1	0	<1	0
Molybdenum	ppm	ASTM D5185m	2	2	2	<1
Manganese	ppm	ASTM D5185m	1	<1	1	<1
Magnesium	ppm	ASTM D5185m	5	9	8	7
Calcium	ppm	ASTM D5185m	1220	1321	1254	1270
Phosphorus	ppm	ASTM D5185m	298	296	289	277
Zinc	ppm	ASTM D5185m	350	363	335	348
Sulfur	ppm	ASTM D5185m	1995	2741	2574	2050

CONTAMINANTS

method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>+100	10	11	1
Sodium	ppm	ASTM D5185m		0	0	2
Potassium	ppm	ASTM D5185m	>20	4	3	<1
Fuel	%	ASTM D3524	>4.0	0.0	0.1	0.2

INFRA-RED


method	limit/base	current	history1	history2		
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	4.0	3.3	11.0
Sulfation	Abs/.1mm	*ASTM D7415	>30	14.0	13.7	19.3

FLUID DEGRADATION


method	limit/base	current	history1	history2		
Oxidation	Abs/.1mm	*ASTM D7414	>25	8.3	7.4	17.9
Acid Number (AN)	mg KOH/g	ASTM D8045	0.86	0.66	0.801	1.02
Base Number (BN)	mg KOH/g	ASTM D2896	3.9	2.65	3.75	3.40

OIL ANALYSIS REPORT


▲ Non-ferrous Metals




Fuel Dilution




FT-IR (Direct Trend)



Acid Number



Base Number




PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


PARAMETER	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.7	13.5	13.1

GRAPHS


Iron (ppm)




Aluminum (ppm)




▲ Copper (ppm)




Viscosity @ 100°C




Lead (ppm)




Chromium (ppm)



Silicon (ppm)



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0112040 **Received** : 09 May 2024
Lab Number : 06174058 **Tested** : 15 May 2024
Unique Number : 11020111 **Diagnosed** : 15 May 2024 - Don Baldrige
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

ENERVEST OPERATING - HAYSI A
 1242 WEST WIND ROAD
 HAYSI, VA
 US 24256
 Contact: CHARLES GREGORY
 cgregory@usacompression.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: