


OIL ANALYSIS REPORT

Sample Rating Trend





Machine Id

DAVIS
Component
Natural Gas Engine
Fluid
PETRO CANADA SEI

PETRO CANADA SENTRON LA 2000 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

Wear

Bearing and/or bushing wear is indicated.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is above the recommended limit. The BN level is low.

RON LA 2000 (- GAL)		Nov2023	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0112187	PCA0112203	
Sample Date		Client Info		09 May 2024	28 Nov 2023	
Machine Age	hrs	Client Info		4049	783	
Oil Age	hrs	Client Info		4049	783	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				ABNORMAL	NORMAL	
CONTAMINATI	ON	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	
WEAR METALS	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	18	8	
Chromium	ppm	ASTM D5185m	>4	<1	0	
Nickel	ppm	ASTM D5185m	>2	<1	0	
Titanium	ppm	ASTM D5185m		<1	0	
Silver	ppm	ASTM D5185m	>3	1	0	
Aluminum	ppm	ASTM D5185m	>9	2	2	
Lead	ppm	ASTM D5185m	>30	45	<1	
Copper	ppm	ASTM D5185m	>35	21	14	
Tin	ppm	ASTM D5185m	>4	1	0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	0	0	
Barium	ppm	ASTM D5185m	1	1	0	
Molybdenum	ppm	ASTM D5185m	1	3	0	
Manganese	ppm	ASTM D5185m	5	<1	0	
Magnesium	ppm	ASTM D5185m	1	21	2	
Calcium	ppm	ASTM D5185m	1237	1603	1415	
Phosphorus	ppm	ASTM D5185m	270	360	292	
Zinc	ppm	ASTM D5185m	330	466	356	
Sulfur	ppm	ASTM D5185m	2670	3838	3791	
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	4	2	
Sodium	ppm	ASTM D5185m		4	3	
Potassium	ppm	ASTM D5185m	>20	3	2	
Fuel	%	ASTM D3524	>4.0	0.4	0.3	
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0	
Nitration	Abs/cm	*ASTM D7624	>20	11.5	7.0	
Sulfation	Abs/.1mm	*ASTM D7415	>30	27.0	17.3	
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2
	Alex/down	*AOTA D7444	>25	07.4	11.0	
Oxidation	Abs/.1mm	*ASTM D7414	>25	27.4	11.8	
Oxidation Acid Number (AN)	mg KOH/g	ASTM D/414 ASTM D8045	0.64	△ 4.77	1.54	



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

Lab Number : 06190724

: PCA0112187 Unique Number : 11047476

Received : 24 May 2024 **Tested** Diagnosed

: 30 May 2024 : 30 May 2024 - Jonathan Hester

Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

GIGA ENERGY - MARSHALL

803 BOIS D ARC MARSHALL, TX US 75672

Contact: BRENT MCINTOSH brent_mcintosh@yahoo.com T: (903)926-9567

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)