


OIL ANALYSIS REPORT

Area
GRIND ROOM [98996224]
 Machine Id
KR-GR-002491 - INCLINE AUGER 8A (S/N GRIND A - 11513018)
 Component
Gearbox
 Fluid
PETRO CANADA 220 (17 QTS)

Sample Rating Trend



DIAGNOSIS

Recommendation
 No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
 All component wear rates are normal.

Contamination
 There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0122297	PCA0116076	PCA0110820
Sample Date	Client Info	24 May 2024	11 Mar 2024	06 Nov 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	16	7	16
Chromium	ppm ASTM D5185m >15	<1	<1	0
Nickel	ppm ASTM D5185m >15	0	0	<1
Titanium	ppm ASTM D5185m	<1	<1	<1
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >25	2	3	0
Lead	ppm ASTM D5185m >100	<1	<1	<1
Copper	ppm ASTM D5185m >200	<1	<1	<1
Tin	ppm ASTM D5185m >25	<1	<1	0
Vanadium	ppm ASTM D5185m	0	<1	0
Cadmium	ppm ASTM D5185m	0	<1	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	<1	<1	0
Molybdenum	ppm ASTM D5185m	<1	0	0
Manganese	ppm ASTM D5185m	<1	<1	1
Magnesium	ppm ASTM D5185m	<1	<1	0
Calcium	ppm ASTM D5185m	2	4	18
Phosphorus	ppm ASTM D5185m	405	447	401
Zinc	ppm ASTM D5185m	2	3	0
Sulfur	ppm ASTM D5185m	1437	1509	2556

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	3	3	2
Sodium	ppm ASTM D5185m	<1	0	2
Potassium	ppm ASTM D5185m >20	1	1	<1

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 110086	▲ 81930	▲ 86437
Particles >6µm	ASTM D7647 >2500	▲ 6149	▲ 8811	▲ 14335
Particles >14µm	ASTM D7647 >640	66	367	276
Particles >21µm	ASTM D7647 >160	9	69	54
Particles >38µm	ASTM D7647 >40	0	0	2
Particles >71µm	ASTM D7647 >10	0	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/16	▲ 24/20/13	▲ 24/20/16	▲ 24/21/15

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	0.46	0.50	0.43

OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	221	224	259

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PCA0122297

Lab Number : 06195368

Unique Number : 11057491

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 30 May 2024

Tested : 31 May 2024

Diagnosed : 31 May 2024 - Angela Borella

KraftHeinz - Kirksville - Plant 8333 PCA

2504 INDUSTRIAL DR

KIRKSVILLE, MO

US 63501

Contact: WALLACE WARD

wallace.ward@kraftheinzcompany.com

T: (660)627-1031

F: (660)627-5887

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)