

OIL ANALYSIS REPORT

Sample Rating Trend



TUMBLE ROOM [98938358]

KR-GR-003067 - TUMBLER 2 (S/N TUMBLE ROOM - 11513090)

Hydraulic System

AW HYDRAULIC OIL ISO 46 (10 GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Appearance is milky. There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

Fluid Condition


Viscosity of sample indicates oil is within ISO 68 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

		Jan 2022	Jul2022 0ct2022	Apr2023 Aug2023 Nov2023	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0122296	PCA0115885	PCA0113109
Sample Date		Client Info		24 May 2024	11 Mar 2024	30 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METAL	S	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	2	1	2
Chromium	ppm	ASTM D5185m	>20	<1	<1	<1
Nickel	ppm	ASTM D5185m	>20	<1	<1	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	2	3	<1
Lead	ppm	ASTM D5185m	>20	<1	<1	0
Copper	ppm	ASTM D5185m	>20	2	3	1
Tin	ppm	ASTM D5185m	>20	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	5	<1	0	0
Molybdenum	ppm	ASTM D5185m	5	<1	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	25	<1	<1	0
Calcium	ppm	ASTM D5185m	200	<1	5	9
Phosphorus	ppm	ASTM D5185m	300	397	472	423
Zinc	ppm	ASTM D5185m	370	3	13	64
Sulfur	ppm	ASTM D5185m	2500	583	709	1106
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	3	4	4
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	1	<1	0
Water	%	ASTM D6304	>0.05	<u> </u>	△ 0.241	
ppm Water	ppm	ASTM D6304	>500	2570	<u>4</u> 2410	
FLUID CLEANL	INESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000			▲ 102985
Particles >6µm		ASTM D7647	>2500			<u>▲</u> 17522
Particles >14μm		ASTM D7647	>640			258
Particles >21µm		ASTM D7647	>160			50
Particles >38μm		ASTM D7647	>40			1
Particles >71μm		ASTM D7647	>10			0
Oil Cleanliness		ISO 4406 (c)	>20/18/16			<u>4</u> 24/21/15
FLUID DEGRAD	OATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.57	0.27	0.25	0.21




Water (KF)


OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	MILKY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	△ 0.2%	NEG
Free Water	scalar	*Visual		NEG	▲ 2.0	NEG
FLUID PROPE	ERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	65.5	66.5	64.4
SAMPLE IMAG	GES	method	limit/base	current	history1	history2
Color						
Bottom						Mark 1

GRAPHS













Certificate 12367

Laboratory Sample No.

Lab Number : 06195375

: PCA0122296 Unique Number : 11057498

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 30 May 2024

Tested : 03 Jun 2024 Diagnosed

: 03 Jun 2024 - Jonathan Hester

KraftHeinz - Kirksville - Plant 8333 PCA 2504 INDUSTRIAL DR KIRKSVILLE, MO US 63501

Test Package : IND 2 (Additional Tests: KF) To discuss this sample report, contact Customer Service at 1-800-237-1369.

wallace.ward@kraftheinzcompany.com T: (660)627-1031

Contact: WALLACE WARD

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: KRAKIR [WUSCAR] 06195375 (Generated: 06/04/2024 08:05:28) Rev: 1

Submitted By: Wilberto Pacheco Garcia

F: (660)627-5887