

OIL ANALYSIS REPORT

Sample Rating Trend



INJECT B ROOM [99015100]

KR-GR-003106 - DUMPER 3B - SOUTH (S/N INJECT B - 11513037)

Hydraulic System

AW HYDRAULIC OIL ISO 68 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

All component wear rates are normal.

Contamination

Appearance is milky. There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		sc2021 Mar2	122 Jun2022 Nov2022	Ápr2023 Sep2023 Óct2023	Marž024	
SAMPLE INFORI	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0122294	PCA0119598	PCA0120396
Sample Number		Client Info		24 May 2024	20 Mar 2024	14 Mar 2024
Machine Age	hrs	Client Info		0	0 IVIAI 2024	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	1115	Client Info		N/A	N/A	N/A
Sample Status		Ciletit IIIIO		ABNORMAL	ABNORMAL	ABNORMAL
WEAR METAL	<u>c</u>	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	2	<1	0
Chromium	ppm	ASTM D5185m	>20	<1	<1	<1
Nickel	ppm	ASTM D5185m	>20	<1	0	0
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	2	3	3
Lead	ppm	ASTM D5185m	>20	<1	<1	<1
Copper	ppm	ASTM D5185m	>20	1	2	1
Tin	ppm	ASTM D5185m	>20	<1	<1	<1
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		<1	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	5	0	0	0
Barium	ppm	ASTM D5185m	5	<1	<1	0
Molybdenum	ppm	ASTM D5185m	5	<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	25	1	<1	<1
Calcium	ppm	ASTM D5185m	200	10	13	12
Phosphorus	ppm	ASTM D5185m	300	411	453	465
Zinc	ppm	ASTM D5185m	370	57	55	60
Sulfur	ppm	ASTM D5185m	2500	785	862	888
CONTAMINAN	TS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	3	3	3
Sodium	ppm	ASTM D5185m		2	1	<1
Potassium	ppm	ASTM D5185m	>20	<1	<1	1
Water	%	ASTM D6304	>0.05	△ 0.226	△ 0.215	
ppm Water	ppm	ASTM D6304	>500	2260	<u></u> 2150	
FLUID CLEAN	INESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000		1575	▲ 59992
Particles >6µm		ASTM D7647	>2500		858	▲ 7749
Particles >14µm		ASTM D7647	>640		146	338
Particles >21µm		ASTM D7647	>160		49	60
Particles >38µm		ASTM D7647	>40		8	3
Particles >71µm		ASTM D7647	>10		1	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16		18/17/14	2 3/20/16
FLUID DEGRAD	DATION	method	limit/base	current	history1	history2
A all al Nicosala a o (ANI)		4.OTM D00.45	0.57	0.00	0.00	0.00

Acid Number (AN)

0.26


0.28


mg KOH/g ASTM D8045 0.57


0.22



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE NONE		NONE	NONE
Yellow Metal	scalar	*Visual	NONE NONE		NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE NONE		NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	MILKY	MILKY	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPE	RTIFS	method	limit/base	current	historv1	history2


Visc @ 40°C	cSt	ASTM D445	68	67.1	72.5	67.2
-------------	-----	-----------	----	------	------	------

method


Color





SAMPLE IMAGES




GRAPHS













Certificate 12367

Laboratory Sample No. Lab Number : 06195379 Unique Number : 11057502

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: PCA0122294

Received : 30 May 2024 **Tested** Diagnosed

: 03 Jun 2024 : 03 Jun 2024 - Jonathan Hester

KraftHeinz - Kirksville - Plant 8333 PCA 2504 INDUSTRIAL DR KIRKSVILLE, MO US 63501

Contact: WALLACE WARD wallace.ward@kraftheinzcompany.com

Test Package : IND 2 (Additional Tests: KF) To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (660)627-5887

Report Id: KRAKIR [WUSCAR] 06195379 (Generated: 06/04/2024 08:05:37) Rev: 1

T: (660)627-1031