


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
WILLMAR
 Machine Id
Unit 01 DB040101E
 Component
Natural Gas Engine
 Fluid
DIESEL ENGINE OIL SAE 40 (250 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. (Customer Sample Comment: 50.5 Gallons Make-up Oil)

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PCA0105951	PCA0105950	PCA0105949
Sample Date	Client Info			30 May 2024	26 Apr 2024	28 Mar 2024
Machine Age	hrs	Client Info		6530	6283	6198
Oil Age	hrs	Client Info		6530	6283	6198
Oil Changed	Client Info			Filtered	Filtered	Filtered
Sample Status				NORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	6	3	6
Chromium	ppm	ASTM D5185m	>4	<1	0	0
Nickel	ppm	ASTM D5185m	>2	<1	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	0	2
Lead	ppm	ASTM D5185m	>30	3	<1	2
Copper	ppm	ASTM D5185m	>35	3	5	2
Tin	ppm	ASTM D5185m	>4	1	<1	2
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		<1	<1	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	250	0	0	1
Barium	ppm	ASTM D5185m	10	0	<1	0
Molybdenum	ppm	ASTM D5185m	100	<1	<1	<1
Manganese	ppm	ASTM D5185m		<1	1	0
Magnesium	ppm	ASTM D5185m	450	917	897	908
Calcium	ppm	ASTM D5185m	3000	1101	1073	1109
Phosphorus	ppm	ASTM D5185m	1150	1030	1164	1096
Zinc	ppm	ASTM D5185m	1350	1348	1315	1326
Sulfur	ppm	ASTM D5185m	4250	3350	3469	3728


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	2	2	3
Sodium	ppm	ASTM D5185m	>216	2	2	3
Potassium	ppm	ASTM D5185m	>20	4	0	3
Fuel	%	ASTM D3524	>4.0	1.4	1.1	1.4

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	4.1	4.0	4.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	13.1	13.0	13.0


FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	6.9	6.9	7.0
Acid Number (AN)	mg KOH/g	ASTM D8045		1.45	1.55	1.46
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	8.66	8.50	8.48

OIL ANALYSIS REPORT


Fuel Dilution




FT-IR (Direct Trend)




Acid Number



Base Number



Viscosity @ 100°C



VISUAL


	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES


	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	13.7	13.6

GRAPHS


Iron (ppm)




Aluminum (ppm)




Copper (ppm)




Viscosity @ 100°C




Lead (ppm)




Chromium (ppm)



Silicon (ppm)



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PCA0105951

Lab Number : 06198327

Unique Number : 11060450

Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 03 Jun 2024

Tested : 05 Jun 2024

Diagnosed : 05 Jun 2024 - Sean Felton

Magellan Midstream LP - Willmar

2131 30th Stree SW

Willmar, MN

US 56201

Contact: Andrew Lauer

andrew.lauer@magellanlp.com

T: (320)808-4364

F: