


OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area
BATCH SYSTEM 3
 Machine Id
BS3 HOMO
 Component
Gearbox
 Fluid
PETRO CANADA ENDURATEX EP 460 (--- LTR)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PCA0119929	PCA0117327	PCA0111052
Sample Date	Client Info	31 May 2024	20 May 2024	18 Nov 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	Not Changed	Not Changed	Not Changed
Sample Status		ABNORMAL	ATTENTION	ABNORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	12	0	121
Chromium	ppm ASTM D5185m >15	0	0	<1
Nickel	ppm ASTM D5185m >15	0	0	1
Titanium	ppm ASTM D5185m	0	0	<1
Silver	ppm ASTM D5185m	0	<1	0
Aluminum	ppm ASTM D5185m >25	0	0	2
Lead	ppm ASTM D5185m >100	0	0	<1
Copper	ppm ASTM D5185m >200	5	<1	1
Tin	ppm ASTM D5185m >25	<1	0	<1
Vanadium	ppm ASTM D5185m	0	0	<1
Cadmium	ppm ASTM D5185m	0	0	<1

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m 55	74	0	56
Barium	ppm ASTM D5185m 0	<1	0	0
Molybdenum	ppm ASTM D5185m 0	8	<1	48
Manganese	ppm ASTM D5185m 0	<1	0	<1
Magnesium	ppm ASTM D5185m 2	0	0	3
Calcium	ppm ASTM D5185m 6	3	50	8
Phosphorus	ppm ASTM D5185m 240	303	367	398
Zinc	ppm ASTM D5185m 3	5	467	29
Sulfur	ppm ASTM D5185m 10310	7739	1078	7377

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	13	12	11
Sodium	ppm ASTM D5185m	0	2	<1
Potassium	ppm ASTM D5185m >20	<1	<1	2

FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	▲ 134403	● 14100	---
Particles >6µm	ASTM D7647 >2500	▲ 33201	1918	---
Particles >14µm	ASTM D7647 >640	▲ 1355	54	---
Particles >21µm	ASTM D7647 >160	▲ 397	12	---
Particles >38µm	ASTM D7647 >40	29	0	---
Particles >71µm	ASTM D7647 >10	7	0	---
Oil Cleanliness	ISO 4406 (c) >20/18/16	▲ 24/22/18	● 21/18/13	---

FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045 0.5	0.51	0.45	0.69

OIL ANALYSIS REPORT


▲ Particle Trend




▲ Particle Trend



Acid Number



Viscosity @ 40°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	452	442	101

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color




Bottom

GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : PCA0119929

Lab Number : 06200115

Unique Number : 11062238

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 05 Jun 2024

Tested : 06 Jun 2024

Diagnosed : 07 Jun 2024 - Don Baldrige

KraftHeinz - Mason City - Plant 8360

1022 12TH ST

MASON CITY, IA

US 50401

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: (641)421-2936