


OIL ANALYSIS REPORT

Galy Line [Galv Line] 670005-# 3 BRIDLE ROLL # 1

Gearbox

PETRO CANADA ENDURATEX EP 220 (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

GAL)		Aug2021	Feb2022 Aug2022	Feb2023 Jul2023 Fe	b2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0117627	PCA0112965	PCA0107666
Sample Date		Client Info		05 Jun 2024	13 Feb 2024	20 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METAL	.S	method	limit/base	current	history1	history2
PQ		ASTM D8184		11	16	
Iron	ppm	ASTM D5185m	>200	4	3	2
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	0
Lead	ppm	ASTM D5185m	>100	0	<1	0
Copper	ppm	ASTM D5185m	>200	0	0	0
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	30	61	52
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0	<1
Magnesium	ppm	ASTM D5185m	0	0	0	<1
Calcium	ppm	ASTM D5185m	0	0	2	4
Phosphorus	ppm	ASTM D5185m	270	262	276	253
Zinc	ppm	ASTM D5185m	0	0	2	0
Sulfur	ppm	ASTM D5185m	11200	7650	6807	6582
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	12	11	10
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	0	0
FLUID DEGRA	DATION	method	limit/base	current	history1	history2
A : 151 1 (A51)	1/011/	4 OT1 4 D00 45	0.40	0.50	0.44	0.40

0.50

Acid Number (AN)


mg KOH/g ASTM D8045 0.40


0.44


0.49



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

I LOID I HOI L	ITTILO					
Visc @ 40°C	cSt	ASTM D445	220	228	229	229

SAMPLE IMAGES

Color

Bottom







Laboratory Sample No.

Lab Number : 06201606 Unique Number : 11063729

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : PCA0117627 Received

: 06 Jun 2024 **Tested** : 07 Jun 2024 Diagnosed : 07 Jun 2024 - Wes Davis

455 West Industrial Drive

Terre Haute, IN US 47802 Contact: BRAD ELLIS

Test Package : PLANT Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SDI - Steel DynamicsInc. - Heartland

brad.ellis@steeldynamics.com

T:

F: