


OIL ANALYSIS REPORT

Galy Line [Galv Line] 670005B-# 3 BRIDLE ROLL # 2

Gearbox

PETRO CANADA ENDURATEX EP 220 (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


GAL)		Aug2021	Feb2022 Aug2022	Feb2023 Jul2023 Fe	b2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PCA0117628	PCA0112966	PCA0107697
Sample Date		Client Info		05 Jun 2024	13 Feb 2024	20 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINAT	ION	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METAL	.S	method	limit/base	current	history1	history2
PQ		ASTM D8184		21	30	
Iron	ppm	ASTM D5185m	>200	110	113	107
Chromium	ppm	ASTM D5185m	>15	<1	<1	1
Nickel	ppm	ASTM D5185m	>15	0	<1	<1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	0	0
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	11	30	28
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	<1	<1	1
Magnesium	ppm	ASTM D5185m	0	0	0	1
Calcium	ppm	ASTM D5185m	0	0	5	7
Phosphorus	ppm	ASTM D5185m	270	254	269	254
Zinc	ppm	ASTM D5185m	0	0	4	<1
Sulfur	ppm	ASTM D5185m	11200	8369	7171	7011
CONTAMINAN	ITS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	15	16	14
Sodium	ppm	ASTM D5185m		2	1	<1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
FLUID DEGRAI	DATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.72	0.67	0.63



OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

LLOID LUOPI		memod			HISTORY	HISTORYZ
Visc @ 40°C	cSt	ASTM D445	220	226	227	227

SAMP		MACI	=0
	<u> </u>	viaui	

Color

Bottom



PQ Ferrous Alloys 150 220 160 140 2 120· 100 Non-ferrous Metals 80 Feb 13/24 Viscosity @ 40°C Acid Number (mg KOH/g) (240 (200+) 220 0.00 G 180 Feb 1/23 -





Certificate 12367

Laboratory Sample No. Unique Number : 11063730

Lab Number : 06201607

: PCA0117628 Test Package : PLANT

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 06 Jun 2024 **Tested** : 07 Jun 2024 Diagnosed

Feb 13/24

: 07 Jun 2024 - Wes Davis

SDI - Steel DynamicsInc. - Heartland 455 West Industrial Drive Terre Haute, IN

US 47802 Contact: BRAD ELLIS

brad.ellis@steeldynamics.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: SDITER [WUSCAR] 06201607 (Generated: 06/07/2024 08:33:48) Rev: 1

Contact/Location: BRAD ELLIS - SDITER

T:

F: