


# OIL ANALYSIS REPORT

## Sample Rating Trend



ISO



Area

**UTILITIES [99027338]**

Machine Id

**COOPER 1 (S/N F13272)**

Component

**Rotary Compressor**

Fluid

**INGERSOLL-RAND TURBOBLEND 46 (30 GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>PCA0117528</b>	PCA0096833	PCA0096836
Sample Date	Client Info	<b>10 Jun 2024</b>	10 Dec 2023	06 Jun 2023
Machine Age	hrs	<b>42982</b>	42897	39938
Oil Age	hrs	<b>0</b>	0	34478
Oil Changed	Client Info	<b>Not Chngd</b>	N/A	Not Chngd
Sample Status		<b>ABNORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.6	<b>NEG</b>	NEG	NEG

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >70	<b>&lt;1</b>	0	0
Chromium	ppm ASTM D5185m >10	<b>&lt;1</b>	<1	<1
Nickel	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Titanium	ppm ASTM D5185m	<b>&lt;1</b>	0	<1
Silver	ppm ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm ASTM D5185m >3	<b>2</b>	2	<1
Lead	ppm ASTM D5185m >4	<b>&lt;1</b>	0	<1
Copper	ppm ASTM D5185m >20	<b>&lt;1</b>	0	0
Tin	ppm ASTM D5185m >3	<b>&lt;1</b>	0	<1
Vanadium	ppm ASTM D5185m	<b>0</b>	0	<1
Cadmium	ppm ASTM D5185m	<b>&lt;1</b>	0	<1

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Barium	ppm ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Manganese	ppm ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm ASTM D5185m	<b>&lt;1</b>	0	0
Calcium	ppm ASTM D5185m	<b>0</b>	1	0
Phosphorus	ppm ASTM D5185m	<b>16</b>	42	11
Zinc	ppm ASTM D5185m	<b>2</b>	0	0
Sulfur	ppm ASTM D5185m	<b>190</b>	0	41

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >45	<b>1</b>	0	<1
Sodium	ppm ASTM D5185m	<b>0</b>	0	2
Potassium	ppm ASTM D5185m >20	<b>&lt;1</b>	1	2

## FLUID CLEANLINESS


method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >1300	<b>▲ 2806</b>	588	324
Particles >6µm	ASTM D7647 >320	<b>▲ 958</b>	121	81
Particles >14µm	ASTM D7647 >80	<b>53</b>	7	12
Particles >21µm	ASTM D7647 >20	<b>11</b>	2	4
Particles >38µm	ASTM D7647 >4	<b>0</b>	0	0
Particles >71µm	ASTM D7647 >3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c) >17/15/13	<b>▲ 19/17/13</b>	16/14/10	16/14/11

## FLUID DEGRADATION


method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g ASTM D8045	<b>0.14</b>	0.13	0.13

# OIL ANALYSIS REPORT


## ▲ Particle Trend




## ▲ Particle Trend



## Acid Number




## Viscosity @ 40°C



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.6	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	46.1	45.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C



### ▲ Particle Count



### Acid Number



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PCA0117528 **Received** : 17 Jun 2024  
**Lab Number** : 06211586 **Tested** : 18 Jun 2024  
**Unique Number** : 11084450 **Diagnosed** : 18 Jun 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**KraftHeinz - Springfield - Plant 8311 PCA**  
 2035 E BENNETT  
 SPRINGFIELD, MO  
 US 65804  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: