


OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
RESIDUE 2
 Component
Natural Gas Engine
 Fluid
PETRO CANADA SENTRON LA 2000 (--- GAL)

DIAGNOSIS

Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Fuel content negligible. There is no indication of any contamination in the oil.

Fluid Condition

The BN level is low. The AN level is at the top-end of the recommended limit.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			PCA0118680	PCA0118689	PCA0118691
Sample Date	Client Info			05 Jun 2024	02 May 2024	18 Mar 2024
Machine Age	hrs	Client Info		52400	53100	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed	Client Info			N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method		>0.1	NEG	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	13	10	3
Chromium	ppm	ASTM D5185m	>4	0	<1	0
Nickel	ppm	ASTM D5185m	>2	1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>9	2	<1	<1
Lead	ppm	ASTM D5185m	>30	2	0	0
Copper	ppm	ASTM D5185m	>35	4	4	0
Tin	ppm	ASTM D5185m	>4	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	<1	0	0
Barium	ppm	ASTM D5185m	1	0	0	0
Molybdenum	ppm	ASTM D5185m	1	0	0	0
Manganese	ppm	ASTM D5185m	5	<1	<1	0
Magnesium	ppm	ASTM D5185m	1	5	3	2
Calcium	ppm	ASTM D5185m	1237	1450	1423	1332
Phosphorus	ppm	ASTM D5185m	270	327	305	278
Zinc	ppm	ASTM D5185m	330	384	374	315
Sulfur	ppm	ASTM D5185m	2670	3992	3811	3625

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>+100	2	1	4
Sodium	ppm	ASTM D5185m		4	<1	<1
Potassium	ppm	ASTM D5185m	>20	3	<1	0
Fuel	%	ASTM D3524	>4.0	0.1	0.1	0.3

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0.1	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	8.9	8.3	6.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	22.3	19.5	16.6

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	21.0	17.2	11.6
Acid Number (AN)	mg KOH/g	ASTM D8045	0.64	▲ 2.85	1.94	1.38
Base Number (BN)	mg KOH/g	ASTM D2896	4.4	▲ 1.94	2.84	3.81









OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.5	14.5	14.2	13.7

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PCA0118680 **Received** : 17 Jun 2024
Lab Number : 06212555 **Tested** : 20 Jun 2024
Unique Number : 11085419 **Diagnosed** : 20 Jun 2024 - Jonathan Hester
Test Package : MOB 2 (Additional Tests: FuelDilution, PercentFuel)

DIVERSIFIED ENERGY - FRIERSON
 1716 FRIENDSHIP RD
 FRIERSON, LA
 US 71027
 Contact: KORRY SHELTON
 kshelton@dgoc.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)